

Marlboro Township Board of Education – Addendum Information for ESIP Bid

December 21, 2018

We have received questions from the companies who are interested in our project. WE have either supplied the answer below or posted the information on the district's website with the bid information. The items we have posted will be so indicated below.

1. The district does participate in a demand response program.
2. HVAC scheduling information will be posted on the district's website.
3. Roof information will be posted on the district's website.
4. Our architect is RYEBREAD Architects, and engineers is Kelter & Gilligo, the fees to be included is \$50,000. They are the district's owner's agent not design professionals.
5. Memorial Middle School should be included in the plan.
6. The district does desire an addressable fire alarm system at Memorial Middle School and at all schools.
7. All utility bills, electric, natural gas, fuel oil, water & sewer bills have been posted to the district's website.
8. The only service contract on existing HVAC controls the district has is with CM3 is in the amount of \$8,936.
9. Asbestos abatement would be done by the district if necessary. Notice by the ESCO must be provided to the district in a timely manner so as not to delay work.
10. Exhibit I should have been included in all sections of the RFP and must be included in the bid submission.