



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J610918

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Madison 2

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 09/21/2016 13:10
Reported: 09/27/2016 12:39

Analytical Testing Parameters

Client Sample ID: 1-1
Lab Sample ID: J610918-01
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/09/16
Collection Time: 06:09

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0061, 0.001, mg/L, 09/23/16 1332, 09/24/16 0450

Analytical Testing Parameters

Client Sample ID: 2-1
Lab Sample ID: J610918-02
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/09/16
Collection Time: 06:08

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0072, 0.001, mg/L, 09/23/16 1332, 09/24/16 0454

Analytical Testing Parameters

Client Sample ID: 3-1
Lab Sample ID: J610918-03
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/09/16
Collection Time: 06:06

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.072, 0.001, mg/L, 09/23/16 1332, 09/24/16 0458



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0918

Analytical Testing Parameters

Client Sample ID: 4-1
Lab Sample ID: J6I0918-04
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/09/16
Collection Time: 06:12

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0063, 0.001, mg/L, 09/23/16 1332, 09/24/16 0502

Analytical Testing Parameters

Client Sample ID: 5-1
Lab Sample ID: J6I0918-05
Sample Type: Grab

Collected By: RF-Client
Collection Date: 09/09/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.014, 0.001, mg/L, 09/23/16 1408, 09/24/16 0505

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 23.0°C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, Item, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc. Dayville (NY 11549)
NY Lab ID No: 11549

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6I0918

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield
Division Manager
09/27/2016 12:39

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MADISON 2

MNY Worker #

Client Information				Billing/Invoice:			
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES				Analysis Requested			
Address: 20104 NYS Route 3				Ice: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>			
Contact: Watertown, NY 13601				Cooler: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>			
Phone: Ray Filley				Sample Temp: 23.0			
Project: 315-779-7054				Cooler Seal: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>			
Quote ID: Lead Testing				Pickup: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>			
Rush TAT Bus. Days: 2-5 5-7 7-10				Dropoff: C W			
Release to DOH: Yes				Accepted? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>			
Email Results: Yes				Container Material			
Fax Results: Yes				Container Size(in MI)			
PO#: rfilley@boces.com / fhauck@boes.com				Preservative			
Date Req:				Comments/Field Data			
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1-1	6:09	9/9	RF				
2-1	6:08	9/9					
3-1	6:06	9/9					
4-1	6:12	9/9					
5-1	6:13	9/9					
6							
7							
8							
Print Name and Company				Signature			
Ray Filley				9/9/15			
David Thomas				9/21/15			
Grandy Walker				7/16/16			
Received:				Received:			
Received:				Received:			
Received:				Received:			
Received:				Received:			
Received:				Received:			



Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this...