



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Mass NI

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 08/09/2016 12:30
Reported: 08/29/2016 21:23

Analytical Testing Parameters

Client Sample ID: 36-1
Lab Sample ID: J6H0736-01
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0018	0.015	0.0010	mg/L		08/19/16 1611	08/22/16 1050

Analytical Testing Parameters

Client Sample ID: 36-2
Lab Sample ID: J6H0736-02
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		08/19/16 1611	08/22/16 1051

Analytical Testing Parameters

Client Sample ID: 38-1
Lab Sample ID: J6H0736-03
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0014	0.015	0.0010	mg/L		08/19/16 1613	08/22/16 1053



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 38-2
Lab Sample ID: J6H0736-04
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1054

Analytical Testing Parameters

Client Sample ID: 35-1
Lab Sample ID: J6H0736-05
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0016, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1056

Analytical Testing Parameters

Client Sample ID: 35-2
Lab Sample ID: J6H0736-06
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0011, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1100



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 34-1
Lab Sample ID: J6H0736-07
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1102

Analytical Testing Parameters

Client Sample ID: 34-2
Lab Sample ID: J6H0736-08
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1107

Analytical Testing Parameters

Client Sample ID: 37-1
Lab Sample ID: J6H0736-09
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0016, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1108



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 37-2
Lab Sample ID: J6H0736-10
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0013, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1110

Analytical Testing Parameters

Client Sample ID: 32-1
Lab Sample ID: J6H0736-11
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1111

Analytical Testing Parameters

Client Sample ID: 32-2
Lab Sample ID: J6H0736-12
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1113



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 18-1
Lab Sample ID: J6H0736-13
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0019, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1114

Analytical Testing Parameters

Client Sample ID: 18-2
Lab Sample ID: J6H0736-14
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1116

Analytical Testing Parameters

Client Sample ID: 21-1
Lab Sample ID: J6H0736-15
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1117



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 21-2
Lab Sample ID: J6H0736-16
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1125

Analytical Testing Parameters

Client Sample ID: 31-1
Lab Sample ID: J6H0736-17
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1126

Analytical Testing Parameters

Client Sample ID: 31-2
Lab Sample ID: J6H0736-18
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0015, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1128



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 24-1
Lab Sample ID: J6H0736-19
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0015, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1129

Analytical Testing Parameters

Client Sample ID: 24-2
Lab Sample ID: J6H0736-20
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1131

Analytical Testing Parameters

Client Sample ID: 30-1
Lab Sample ID: J6H0736-21
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0011, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1132



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 30-2
Lab Sample ID: J6H0736-22
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1134.

Analytical Testing Parameters

Client Sample ID: 22-1
Lab Sample ID: J6H0736-23
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0020, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1135.

Analytical Testing Parameters

Client Sample ID: 22-2
Lab Sample ID: J6H0736-24
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0011, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1137.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 29-1
Lab Sample ID: J6H0736-25
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0023, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1138

Analytical Testing Parameters

Client Sample ID: 29-2
Lab Sample ID: J6H0736-26
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0015, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1146

Analytical Testing Parameters

Client Sample ID: 14-1
Lab Sample ID: J6H0736-27
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1148



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 14-2
Lab Sample ID: J6H0736-28
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1149

Analytical Testing Parameters

Client Sample ID: 20-1
Lab Sample ID: J6H0736-29
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0016, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1151

Analytical Testing Parameters

Client Sample ID: 20-2
Lab Sample ID: J6H0736-30
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1152



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 7-1
Lab Sample ID: J6H0736-31
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0024, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1154

Analytical Testing Parameters

Client Sample ID: 7-2
Lab Sample ID: J6H0736-32
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/19/16 1613, 08/22/16 1155

Analytical Testing Parameters

Client Sample ID: 6-1
Lab Sample ID: J6H0736-33
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0051, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1511



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 6-2
Lab Sample ID: J6H0736-34
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0013, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1513

Analytical Testing Parameters

Client Sample ID: 1-1
Lab Sample ID: J6H0736-35
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0049, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1517

Analytical Testing Parameters

Client Sample ID: 1-2
Lab Sample ID: J6H0736-36
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0014, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1519



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 40-1
Lab Sample ID: J6H0736-37
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0011, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1524.

Analytical Testing Parameters

Client Sample ID: 40-2
Lab Sample ID: J6H0736-38
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1525.

Analytical Testing Parameters

Client Sample ID: 13-1
Lab Sample ID: J6H0736-39
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1527.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 13-2
Lab Sample ID: J6H0736-40
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1528

Analytical Testing Parameters

Client Sample ID: 23-1
Lab Sample ID: J6H0736-41
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0011, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1530

Analytical Testing Parameters

Client Sample ID: 23-2
Lab Sample ID: J6H0736-42
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1531



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 25-1
Lab Sample ID: J6H0736-43
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0061, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1533.

Analytical Testing Parameters

Client Sample ID: 25-2
Lab Sample ID: J6H0736-44
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1534.

Analytical Testing Parameters

Client Sample ID: 17-1
Lab Sample ID: J6H0736-45
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0019, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1536.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 17-2
Lab Sample ID: J6H0736-46
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0011, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1543.

Analytical Testing Parameters

Client Sample ID: 19-1
Lab Sample ID: J6H0736-47
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1545.

Analytical Testing Parameters

Client Sample ID: 19-2
Lab Sample ID: J6H0736-48
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1547.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 15-1
Lab Sample ID: J6H0736-49
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0013, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1548.

Analytical Testing Parameters

Client Sample ID: 15-2
Lab Sample ID: J6H0736-50
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1550.

Analytical Testing Parameters

Client Sample ID: 27-1
Lab Sample ID: J6H0736-51
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.032, 0.015, 0.0010, mg/L, G, 08/22/16 1144, 08/22/16 1551.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 27-2
Lab Sample ID: J6H0736-52
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0028, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1553

Analytical Testing Parameters

Client Sample ID: 28-1
Lab Sample ID: J6H0736-53
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0024, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1554

Analytical Testing Parameters

Client Sample ID: 28-2
Lab Sample ID: J6H0736-54
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1556



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 16-1
Lab Sample ID: J6H0736-55
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1600

Analytical Testing Parameters

Client Sample ID: 16-2
Lab Sample ID: J6H0736-56
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1605

Analytical Testing Parameters

Client Sample ID: 11-1
Lab Sample ID: J6H0736-57
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0011, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1606



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 11-2
Lab Sample ID: J6H0736-58
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1608

Analytical Testing Parameters

Client Sample ID: 33-1
Lab Sample ID: J6H0736-59
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0011, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1609

Analytical Testing Parameters

Client Sample ID: 33-2
Lab Sample ID: J6H0736-60
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0013, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1611



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 12-1
Lab Sample ID: J6H0736-61
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0094, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1613

Analytical Testing Parameters

Client Sample ID: 12-2
Lab Sample ID: J6H0736-62
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/22/16 1144, 08/22/16 1614

Analytical Testing Parameters

Client Sample ID: 4-1
Lab Sample ID: J6H0736-63
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1518



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 4-2
Lab Sample ID: J6H0736-64
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1519

Analytical Testing Parameters

Client Sample ID: 26-1
Lab Sample ID: J6H0736-65
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0020, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1521

Analytical Testing Parameters

Client Sample ID: 26-2
Lab Sample ID: J6H0736-66
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1525



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 8-1
Lab Sample ID: J6H0736-67
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1527.

Analytical Testing Parameters

Client Sample ID: 8-2
Lab Sample ID: J6H0736-68
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1532.

Analytical Testing Parameters

Client Sample ID: 39-1
Lab Sample ID: J6H0736-69
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1533.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 39-2
Lab Sample ID: J6H0736-70
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1534

Analytical Testing Parameters

Client Sample ID: 10-1
Lab Sample ID: J6H0736-71
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1536

Analytical Testing Parameters

Client Sample ID: 10-2
Lab Sample ID: J6H0736-72
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1538



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 5-1
Lab Sample ID: J6H0736-73
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0017, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1539

Analytical Testing Parameters

Client Sample ID: 5-2
Lab Sample ID: J6H0736-74
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1543

Analytical Testing Parameters

Client Sample ID: 9-1
Lab Sample ID: J6H0736-75
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0011, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1544



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Analytical Testing Parameters

Client Sample ID: 9-2
Lab Sample ID: J6H0736-76
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1552

Analytical Testing Parameters

Client Sample ID: 2-1
Lab Sample ID: J6H0736-77
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0051, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1553

Analytical Testing Parameters

Client Sample ID: 2-2
Lab Sample ID: J6H0736-78
Sample Type: Grab

Collected By: RF/FH
Collection Date: 08/03/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 08/24/16 1330, 08/24/16 1555

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
PQL: Practical Quantitation Limit
G: Result fails applicable NYS drinking water standards



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0736

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863

New York State Department of Health
Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield
Division Manager
08/29/2016 21:23

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MASS AU MNY Workorder # _____

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)		
Name: Jefferson-Lewis-Hamilton-Herkimer-Onida BOCES			20104 NYS Route 3			Ice: YES NO			Cooler: YES NO		
Address: Watertown, NY 13601			Ray Filley			Sample Temp:			Cooler seal: YES NO		
Contact: Ray Filley			315-779-7054			Pickup: YES NO			Dropoff: C W		
Phone: Lead Testing			Quote ID: _____			Accepted? YES NO			Container Material		
Project: Lead Testing			PO#: _____			Container Size (in MI)			Preservative		
Date Req: _____			Ruth TAT Bus. Days: < 2-5 5-7 7-10			Number of Containers for Analysis Requested			Comments/Field Data		
Release to DOH: Yes			Email Results: Yes			Matrix Type					
Fax Results: Yes			fillew@booces.com / fhauck@booces.com			Date					
Sample Information			Sample Information			Sample Information			Sample Information		
Description/Location	Date	Time	Initial	Initial	Time	Date	Time	Initial	Initial	Time	Date
1 36-1	8/3	7:53	RF	FH	7:54						
2 36-2		7:54			7:52						
3 38-1		7:52			7:53						
4 38-2		7:53			7:50						
5 35-1		7:50			7:57						
6 35-2		7:57									
7											
8											
Print Name and Company			Signature			Date/Time			Comments		
Sampled: Guy Filley FRED Auck			[Signature]			8/4 1200					
Received: [Signature]			[Signature]			8/16 1230					
Received: [Signature]			[Signature]			8/16 1230					
Received: [Signature]			[Signature]			8/16 1230					
Received: [Signature]			[Signature]			8/16 1230					



J6H0736

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Corland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY000935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MASS AGI

MNY Workorder #

Client Information			Billing/Invoice:			Analyses Requested			Receiving Info (Lab Use Only)			
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES	NO				
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES	NO				
Contact:	Ray Filley					Sample Temp:	YES	NO				
Phone:	315-779-7054					Cooler Seal:	YES	NO				
Project:	Lead Testing					Pickup:	YES	NO				
Quote ID:		PO#:				Dropoff:	C	W				
Rush TAT Bus. Days:	2-5 5-7 7-10		Date Req.:			Accepted?	YES	NO				
Release to DOH: Yes	Yes					Container Material						
Email Results:	Yes		Email:	rfiley@boCES.com / fhauck@boCES.com		Container Size (in MI)						
Fax Results:	Yes					Preservative						
Sample Information			Number of Containers for Analysis Requested			Comments/Field Data						
Description/Location	Date	Time	Initial	Matrix Type								
1 34-1	8/3	7:50	RF									
2 34-2		7:57	FX									
3 37-1		7:57										
4 37-2		7:59										
5 32-1		7:48										
6 32-2		7:49										
7 18-1		7:53										
8 18-2		7:34										
Print Name and Company			Signature			Date/Time						
Sampled: Ray Filley Free Area			Ray Filley			8/4/00						
Received: David Brown ES			[Signature]			8/8/00 12:30						
Received:												
Received:												
Received:												
Received:												

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MASS NJ
 MNY Workorder #

Client Information		Billing/Invoice:				Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES							Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601							Cooler:	YES NO
Contact:	Ray Filley							Sample Temp:	YES NO
Phone:	315-779-7054							Cooler Seal:	YES NO
Project:	Lead Testing							Pickup:	YES NO
Quote ID:								Dropoff:	C W
Rush TAT Bus. Days:	2-5 5-7 7-10							Accepted?	YES NO
Release to DOH:	Yes							Container Material:	
Email Results:	Yes	filley@boces.com						Container Size (in MI):	
Fax Results:	Yes	ffhack@boces.com						Preservative:	
								Comments/Field Data	

Sample Information				Number of Containers for Analysis Requested		Comments
Description/Location	Date	Time	Initial	Matrix Type		
1 21-1	8/3	7:38	RF			
2 21-2		7:39	FH			
3 31-1		7:46				
4 31-2		7:46				
5 24-1		7:42				
6 24-2		7:43				
7 30-1		7:40				
8 30-2		7:47				

Print Name and Company	Signature	Date/Time
Sampled: Ray Filley FRO Huck	<i>[Signature]</i>	8/4 1200
Received: Dan Thomas	<i>[Signature]</i>	8/4/16 1230
Received:		
Received:		
Received:		
Received:		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MASS NJ

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Otsego BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	2 2-5 5-7 7-10	Date Req.:				Accepted:	YES NO
Release to DOH:	Yes					Container Material:	
Email Results:	Yes	rfilley@boces.com				Container Size (in MI):	
Fax Results:	Yes	rfilley@boces.com / fhawck@boces.com				Preservative:	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
1 22-1	8/3	7:37	RF				
2 22-2		7:38	FH				
3 29-1		7:43					
4 29-2		7:44					
5 14-1		7:32					
6 14-2		7:33					
7 20-1		7:35					
8 20-2		7:36					
Print Name and Company		Signature		Date/Time		Comments	
Raymond P. ...		<i>[Signature]</i>		8/16/2008			
David Thomas		<i>[Signature]</i>		8/16/2008			
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

MASS NJ

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Berkimer_Oneida_BOCES			Ice:	YES NO	Container Material	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO	Container size(in MI)	YES NO
Contact:	Ray Filley			Sample Temp:		Preservative	
Phone:	315-779-7054			Cooler Seal:	YES NO		
Project:	Lead Testing			Pickup:	YES NO		
Quote ID:		PO#:		Dropoff:	C W		
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:		Accepted?	YES NO		
Release to DOH:	Yes						
Email Results:	Yes	rfilley@boces.com					
Fax Results:	Yes	f.hack@boces.com					

Sample Information			Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Initial	Matrix Type	
1 7-1	8/3	7:19	RF		
2 7-2		7:20	FH		
3 6-1		7:17			
4 6-2		7:18			
5 1-1		7:17			
6 1-2		7:18			
7 40-1		7:28			
8 40-2		7:29			

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Received:	Raymond Filley Fred Hawk		8/3/08	
Received:	Daniel Thomas		8/9/16 12:30	
Received:				
Received:				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Corland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY000935

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

MASS AIT

Client's Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES						Ice: YES NO	
Address: 20104 NYS Route 3 Watertown, NY 13601						Cooler: YES NO	
Contact: Ray Filley						Sample Temp: YES NO	
Phone: 315-779-7054						Cooler Seal: YES NO	
Project: Lead Testing						Pickup: YES NO	
Quote ID: PO#:						Dropoff: C W	
Ruth TAT Bus. Days: <2 2-5 5-7 7-10 Date Req:						Accepted? YES NO	
Release to DOH: Yes						Container Material	
Email Results: Yes		Email: rfilley@booces.com / fhauck@booces.com				Container Size (in MI)	
Fax Results: Yes						Preservative	
						Comments/Field Data	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 13-1	8/3	7:28	RF				
2 13-2		7:29	FA				
3 23-1		7:40					
4 23-2		7:41					
5 25-1		7:40					
6 25-2		7:41					
7 17-1		7:35					
8 17-2		7:36					
Sampled: Ray Filley Fred Hauck Received: David Thomas				Signature: [Signatures]		Date/Time: 8/14/08 8/16/08	
Received:							
Received:							
Received:							
Received:							
<p>Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.</p>							

3821 Buck Drive
 Corlind NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY000935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MASS NJ
 MNY Workorder #

Client Information		Billing/Invoice:		Analytic Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES Address: 20104 NYS Route 3 Watertown, NY 13601 Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing Quote ID: PO#:		Rush TAT Bus. Days: < 2-5 5-7 7-10 Release to DOH: Yes Email Results: Yes Fax Results: Yes		200.8 Lead P 250 HNO3		Ice: YES NO Cooler: YES NO Sample Temp: YES NO Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material Container Size (in MI) Preservative	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			Comments/Field Data
1 19-1	8/13	7:37	RF PH				
2 19-2		7:38					
3 15-1		7:30					
4 15-2		7:31					
5 27-1		7:08					
6 27-2		7:09					
7 28-1		7:14					
8 28-2		7:15					
Print Name and Company				Signature		Date/Time	
Sampled: Ray Filley FRED ANCK				[Signature]		8/14/200	
Received: David Thomas				[Signature]		8/22/16 1200	
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MASS NJ

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES Address: 20104 NYS Route 3 Watertown, NY 13601 Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing Quote ID: PO#: Rush TAT Bus. Days: 2-5 5-7 7-10 Date Req:		Email Results: Yes rfilley@boces.com Fax Results: Yes fhawk@boces.com		Ice: YES NO Coolers: YES NO Sample Temp: Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material Container size(in MI) Preservative Comment/Field Data			
Sample Information Description/Location Date Time Initial Matrix Type				Number of Containers for Analysis Requested			
1	10-1	8/3	7:31	RF			
2	10-2		7:32	FH			
3	11-1		7:24				
4	11-2		7:25				
5	33-1		7:49				
6	33-2		7:49				
7	12-1		7:27				
8	12-2		7:28				
Print Name and Company Sampled: Ray Filley Fred Hood <i>[Signature]</i> Date/Time: 8/12/08				Signature Date/Time: 8/12/08			
Received: Dale Thomas <i>[Signature]</i> Date/Time: 8/12/08				Signature Date/Time: 8/12/08			
Received:				Signature			
Received:				Signature			
Received:				Signature			
Received:				Signature			
Comments							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY000935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MASS AT MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)			
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		Ice:	YES	NO							
Address:	20104 NYS Route 3 Watertown, NY 13601		Cooler:	YES	NO							
Contact:	Ray Filley		Sample Temp:	YES	NO							
Phone:	315-779-7054		Cooler Seal:	YES	NO							
Project:	Lead Testing		Pickup:	YES	NO							
Quote ID:	PO#:		Dropoff:	C	W							
Rush TAT Bus. Days: < 2-5 5-7 7-10	Date Req:		Accepted?	YES	NO							
Release to DOH: Yes	Email Results: Yes		Container Material									
Box Results: Yes	Fax Results: Yes		Container Size (in MI)									
	Email Results: <u>rfilley@boces.com</u>		Preservative									
	Fax Results: <u>rfilley@boces.com / fhawck@boce5.com</u>		Comments/Field Data									
Sample Information			Number of Containers for Analysis Requested									
Description/Location	Date	Time	Initial	Matrix Type								
1 4-1	8/3	7:15	RF									
2 4-2		7:16	FIH									
3 26a-1		7:10										
4 26a-2		7:11										
5 8-1		7:22										
6 8-2		7:23										
7 39-1		7:55										
8 39-2		7:56										
Print Name and Company			Signature			Date/Time						
Sampled: Raymond Frey Fred Aard						8/4 12:00						
Received: David Thomas						8/9/16 12:30						
Received:												
Received:												
Received:												
Received:												

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MASS AZ

MNY Workorder #

Client Information		Billing/Invoice:	
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES			
Address: 20104 NYS Route 3 Watertown, NY 13601			
Contact: Ray Filley			
Phone: 315-779-7054			
Project: Lead Testing			
Quote ID: _____		PO#: _____	
Rush TAT Bur. Days: <2 2-5 5-7 7-10		Date Req: _____	
Release to DOH: Yes			
Email Results: Yes		Email: rfilley@boces.com	
Fax Results: Yes		Fax: fhawck@boces.com	
Sample Information			
Description/Location	Date	Time	Initial
1 10-1	8/3	7:25	RF FH
2 10-2		7:26	
3 5-1		7:21	
4 5-2		7:22	
5 9-1		7:21	
6 9-2		7:22	
7 2-1		7:19	
8 2-2		7:20	
Matrix Type			
200.8 Lead			
P			
250			
HNO3			
Analysis Requested			
Ice: YES NO			
Cooler: YES NO			
Sample Temp: YES NO			
Cooler feat: YES NO			
Pickup: YES NO			
Dropoff: C W			
Accepted? YES NO			
Container Material			
Container size (in MI)			
Preservative			
Comments/Field Data			
Number of Containers for Analysis Requested			
Date/Time			
Signature			
Print Name and Company			
Comments			
Sampled: Ray Filley BBO Acad 8/11/12			
Received: David Ramos 8/11/12			
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.