

**CERTIFICATE OF ANALYSIS**

Customer : Trinity Hall
101 Corregidor Road
Tinton Falls, NJ 07724

Project ID : Trinity Hall Lead Testing
PAS Project ID : P17-0216

Matrix :
Report Date :

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled
P17-0216-01	Field Blank	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:07
P17-0216-02	Nurses Office (POE)	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:10
P17-0216-03	Chem Lab 108	Lead	2.58	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:22
P17-0216-04	Chem Lab 108 (Flush)	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:23
P17-0216-05	Bio Lab 106	Lead	5.63	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:35
P17-0216-06	Bio Lab 106 (Flush)	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:36
P17-0216-07	Science Prep 106A	Lead	14.7	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:42
P17-0216-08	Science Prep 106A (Flush)	Lead	0.480 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:43
P17-0216-09	Physics Lab 104	Lead	2.82	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:50
P17-0216-10	Physics Lab 104 (Flush)	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:51
P17-0216-11	Engineer Lab 102	Lead	1.65 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:57
P17-0216-12	Engineer Lab 102 (Flush)	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 09:58
P17-0216-13	Faculty Room 100	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:05
P17-0216-14	Faculty Room 100 (Flush)	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:06
P17-0216-15	Water Cooler WF-B	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:15
P17-0216-16	Water Cooler WF-B (15 Min Flush)	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:30
P17-0216-17	Water Cooler WF-C	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:32
P17-0216-18	Water Cooler WF-C (15 Min Flush)	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:47
P17-0216-19	Nurses Office (POE) (Flush)	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	1/16/17 10:50

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

* Federal Action Level

All samples are analyzed in accord
New Jersey Department of Environ
Protection Protocol

Mark D. Feitelson, Lab. I

Drinking Water

01/27/17

Date Analyzed
1/20/17 13:23
1/20/17 13:36
1/20/17 13:40
1/20/17 13:48
1/20/17 14:01
1/20/17 14:05
1/20/17 14:09
1/20/17 14:22
1/20/17 14:26
1/20/17 14:31
1/20/17 14:35
1/20/17 14:39
1/20/17 14:43
1/20/17 14:48
1/20/17 14:52
1/20/17 14:56
1/20/17 15:21
1/20/17 15:25
1/20/17 15:29

in compliance with
environmental



Director