



State Water Resources Control Board

Division of Drinking Water

Lead and Copper Tap Sample Results Reporting Form

This form must be submitted by the public water system to the regulating entity (DDW District Office or County Agency) for each round of lead and copper sampling

Report Date: <small>(mm/dd/yyyy)</small>	10/15/19
Water System Name:	WASHINGTON SCHOOL
Water System Number:	2400071
Water System Type:	<input type="radio"/> Community <input checked="" type="radio"/> Non-Transient, Non Community
Monitoring Frequency:	<input type="radio"/> 6-month <input type="radio"/> Annual <input checked="" type="radio"/> Triennial
# of Samples Required:	5
# of Samples Reported:	5
90th Percentile Level (mg/L)	
Lead: <small>Action Level = 0.015 mg/L</small>	0
Copper: <small>Action Level = 1.3 mg/L</small>	0.26

	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Result	
				Lead (mg/L)	Copper (mg/L)
01	9/11/19	Outside Fountain Gym-4402 W.Oakdale RD,Winton,95388		0	0
02	9/11/19	Outside Fountain Office-4402 W.Oakdale RD,Winton,95388		0	0.34
03	9/11/19	Outside Fountain Room 3-4402 W. Oakdale RD,Winton,95388		0	0.18
04	9/11/19	TMC Room - 4402 W. Oakdale RD,Winton,95388		0	0.086
05	9/11/19	Cafeteria Sink-4402 W. Oakdale RD,Winton,95388		0	0.075
06					
07					
08					
09					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					