



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: MHSS 22

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 11/07/2016 14:00
Reported: 12/27/2016 15:23

Analytical Testing Parameters

Client Sample ID: 118
Lab Sample ID: J6K0413-01
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0112	0.0150	0.00100	mg/L		12/07/16 0800	12/09/16 2208

Analytical Testing Parameters

Client Sample ID: 119
Lab Sample ID: J6K0413-02
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00854	0.0150	0.00100	mg/L		12/07/16 0800	12/09/16 2209

Analytical Testing Parameters

Client Sample ID: 123 E
Lab Sample ID: J6K0413-03
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00430	0.0150	0.00100	mg/L		12/07/16 0800	12/09/16 2210



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 120
Lab Sample ID: J6K0413-04
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0166, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2210

Analytical Testing Parameters

Client Sample ID: 124
Lab Sample ID: J6K0413-05
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0118, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2211

Analytical Testing Parameters

Client Sample ID: 128
Lab Sample ID: J6K0413-06
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00434, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2212



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 138 E
Lab Sample ID: J6K0413-07
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00929, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2212

Analytical Testing Parameters

Client Sample ID: 133
Lab Sample ID: J6K0413-08
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0665, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2213

Analytical Testing Parameters

Client Sample ID: 121
Lab Sample ID: J6K0413-09
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00429, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2214



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 122
Lab Sample ID: J6K0413-10
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00611, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2216

Analytical Testing Parameters

Client Sample ID: 117
Lab Sample ID: J6K0413-11
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0159, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2218

Analytical Testing Parameters

Client Sample ID: 125
Lab Sample ID: J6K0413-12
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0113, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2218



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 127
Lab Sample ID: J6K0413-13
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00501, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2219

Analytical Testing Parameters

Client Sample ID: 130 E
Lab Sample ID: J6K0413-14
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00332, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2220

Analytical Testing Parameters

Client Sample ID: 146
Lab Sample ID: J6K0413-15
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0205, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2220



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 137
Lab Sample ID: J6K0413-16
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0152, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2221

Analytical Testing Parameters

Client Sample ID: 136
Lab Sample ID: J6K0413-17
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0239, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2222

Analytical Testing Parameters

Client Sample ID: 134
Lab Sample ID: J6K0413-18
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0258, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2224



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 135
Lab Sample ID: J6K0413-19
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0459, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2224

Analytical Testing Parameters

Client Sample ID: 131
Lab Sample ID: J6K0413-20
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0208, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2225

Analytical Testing Parameters

Client Sample ID: 140
Lab Sample ID: J6K0413-21
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00304, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2227



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 139
Lab Sample ID: J6K0413-22
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0107, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2227

Analytical Testing Parameters

Client Sample ID: 142
Lab Sample ID: J6K0413-23
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0227, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2228

Analytical Testing Parameters

Client Sample ID: 141
Lab Sample ID: J6K0413-24
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0124, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2229



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 144
Lab Sample ID: J6K0413-25
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0236, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2229

Analytical Testing Parameters

Client Sample ID: 145
Lab Sample ID: J6K0413-26
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0132, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2231

Analytical Testing Parameters

Client Sample ID: 154
Lab Sample ID: J6K0413-27
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00763, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2232



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 155
Lab Sample ID: J6K0413-28
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00140, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2233

Analytical Testing Parameters

Client Sample ID: 148
Lab Sample ID: J6K0413-29
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00338, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2233

Analytical Testing Parameters

Client Sample ID: 147
Lab Sample ID: J6K0413-30
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0331, 0.015, 0.00500, mg/L, 12/14/16 0919, 12/15/16 1305



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 132
Lab Sample ID: J6K0413-31
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0263, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2234

Analytical Testing Parameters

Client Sample ID: 126
Lab Sample ID: J6K0413-32
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0143, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2236

Analytical Testing Parameters

Client Sample ID: 129
Lab Sample ID: J6K0413-33
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00591, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2237



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 149
Lab Sample ID: J6K0413-34
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0159, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2237

Analytical Testing Parameters

Client Sample ID: 150
Lab Sample ID: J6K0413-35
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0119, 0.0150, 0.00100, mg/L, 12/07/16 0800, 12/09/16 2239

Analytical Testing Parameters

Client Sample ID: 152
Lab Sample ID: J6K0413-36
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0151, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2240



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Analytical Testing Parameters

Client Sample ID: 142
Lab Sample ID: J6K0413-37
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0218, 0.0150, 0.00100, mg/L, G, 12/07/16 0800, 12/09/16 2242

Analytical Testing Parameters

Client Sample ID: 153
Lab Sample ID: J6K0413-38
Sample Type: Grab

Collection Date: 10/27/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.119, 0.0150, 0.00100, mg/L, GE, 12/07/16 0800, 12/09/16 2243

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
E: Estimated result
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, No, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland NY Lab ID No: 12006 Pennsylvania Department of Environmental Protection
PA DEP ID: 68-04863



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0413

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield
Division Manager
12/27/2016 15:23

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc. Samples must be returned on Ice
CHAIN OF CUSTODY

MASS 22

MNY Workorder #

Analysis Requested

Client Information
 Name: Jefferson-Lewis-Hamilton-Herkimer-Onida BOCES
 Address: 20104 NYS Route 3
 Watertown, NY 13601
 Contact: Ray Filley
 Phone: 315-779-7054
 Project: Lead Testing
 Quote ID: PO#:
 Rush TAT Bur. Days: 3 2-5 5-7 7-10 Date Req.:
 Release to DOH: Yes
 Email Results: Yes
 Fax Results: Yes
 Email: rfilley@boces.com / rfilley@poc5.com

Sample Information			Matrix	Number of Containers for Analysis Requested	
Description/Location	Date	Time	Type		
1 118	10/27	643	RF		
2 119		643			
3 123 E		643			
4 120		644			
5 124		639			
6 128		640			
7					
8					

200.8 Lead
 P
 250
 HNO3

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: YES NO
 Cooler Seal: YES NO
 Pick up: YES NO
 Drop off: C W
 Accepted: YES NO
 Container Material:
 Container Size (in MI)
 Preservative:
 Comments/Field Data

Print Name and Company
 Sampled: Ray Filley
 Received: Jessica Howard Microbac
 Received: Jessica Howard
 Received:
 Received:
 Received:
 Received:
 Date/Time: 10:00
 14:00
 Signature: Jessica Howard
 Comments:



J6K0413

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

3521 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

MASS 22
 MNY Workorder #

Client Information
 Name: Jefferson-Lewis-Hamilton-Hartman Onelia BOCES
 Address: 20104 NYS Route 3
 Watertown, NY 13601
 Contact: Ray Filley
 Phone: 315-779-7054
 Project: Lead Testing
 Quote ID: _____
 Rush TAT Bus. Days: 2-5 5-7 7-10 PO#: _____
 Release to DOH: Yes Date Req: _____
 Email Results: Yes rfilley@boces.com / fhauck@boces.com
 Fax Results: Yes

Client Information				Billing/Invoice				Analysis Requested				Receiving Info (Lab Use Only)			
Sample Information				Matrix				Number of Containers for Analysis Requested				Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix	Type							Ice:	YES	NO	
1 146	10/27	625	RF	200.8 Lead	P							Container Material			
2 137		631										Container size (in MI)			
3 136		631										Preservative			
4 134		631										Accepted?	YES	NO	
5 135		631										Container Material			
6 131		635										Container size (in MI)			
7 140		630										Preservative			
8 139		630										Accepted?	YES	NO	
Print Name and Company				Signatures				Date/Time				Comments			
Sampled: Ray Filley				[Signature]											
Received: Jessica Howard Microbac				[Signature]				14:00							
Received:															
Received:															
Received:															
Received:															

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and not in...

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MASS 22

MNY Workorder #

Client Information		Billing/Invoice		Analysis Requested		Receiving Info (Lab Use Only)									
Name:	Jefferson-Lewis-Hamilton-Heckler-Oneida BOCES			Ice:	YES NO	Container Material:	YES NO								
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO	Container size (in ML)	YES NO								
Contact:	Ray Filley			Sample Temp:		Preservative:									
Phone:	315-779-7054			Cooler seal:	YES NO	Accepted?	YES NO								
Project:	Lead Testing			Pickup:	YES NO	Dropoff:	C W								
Quote ID:															
Rush TAT Bur. Days:	3 2-5 5-7 7-10	PO#:													
Release to DOH: Yes		Date Req:													
Email Results: Yes															
Fax Results: Yes															
	filley@boces.com / ffilley@boes.com														
	200.8 Lead														
	P														
	250														
	HNO3														
Sample Information				Number of Containers for Analysis Requested				Comments/Field Data							
Description/Location	Date	Time	Initial	Matrix Type											
1 142	10/27	625	RF												
2 141		625													
3 144		626													
4 145		627													
5 154		618													
6 155		618													
7 148 E		625													
8 147		625													
Print Name and Company				Signature				Date/Time				Comments			
Sampled: Ray Filley															
Received: Jessica Howard Microbac								14:00							
Received:															
Received:															
Received:															
Received:															

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY

MASS 22

MNY Workorder #

Client Information				Billing/Invoice			
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES				Analysis Requested			
Address: 20104 NYS Route 3				Ice: YES NO			
Contact: Watertown, NY 13601				Cooler: YES NO			
Phone: Ray Filley				Sample Temp: YES NO			
Project: 315-779-7054				Cooler Seal: YES NO			
Queue ID: Lead Testing				Pickup: YES NO			
Rush TAT Bur. Days: 2-5 5-7 7-10				Dropoff: C W			
Reference to DOH: Yes				Accepted? YES NO			
Email Results: Yes				Container Material			
Fax Results: Yes				Container Size (in ML)			
PO#: 200.8 Lead				Preservative			
Date Req: P				Comments/Field Data			
Email: rfilley@boces.com				Number of Containers for Analyst Requested			
Fax: frack@boces.com				Matrix			
Date: 10/27				Type			
Time: 6:35				Initial: RF			
1	132						
2	126a		6:40				
3	129		6:40				
4	149		6:46				
5	150		6:17				
6	152		6:17				
7	143		6:26				
8	153		6:18				

Print Name and Company	Signature	Date/Time	Comments
Ray Filley	<i>[Signature]</i>		
Jessica Howard Microbac	<i>[Signature]</i>	14:00	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.