

February 14, 2019

Aedis Architects  
387 S. First St., Suite 300  
San Jose, CA 95113

**Subject: Guy Emanuele Jr. Elementary School Drop-Off Zone**  
New Haven Unified School District  
Aedis Project No. 2018003  
NHUSD Project No. 711

### ADDENDUM NO. 1

---

CHANGES AND/OR CLARIFICATIONS OF THE DRAWINGS AND SPECIFICATIONS ARE AS FOLLOWS:

#### RESPONSES TO REQUESTS FOR INFORMATION

ITEM NO. 1.1: QUESTION: There are a few references to the contractor mobilizing a field office trailer. Can you verify that will not be required for this project?  
Response: No field office trailer is required.

ITEM NO. 1.2: QUESTION: Page 69 refers to the contractor obtaining and paying for permits. Can you confirm that no city permits will be required?  
Response: No city permits are required.

ITEM NO. 1.3: QUESTION: Can you confirm what type of truncated domes will be required? Plans show a 12" concrete paver. Wausau tile is typical of this type of paver.  
<http://www.tecturadesigns.com/products/pavers/detectable-warning-ada-pavers>  
A cheaper option would be Armor-Tile similar to what is on site already.  
<https://armor-tile.com/cast-in-place.html>  
Both are available in the 2.35" spacing you were concerned about.  
Response: Cast in place Armor-Tile is an acceptable substitute.

#### GENERAL NOTES

ITEM NO. 1.4: BIDDING RFI'S  
All questions about the meaning or intent of the Contract Documents are to be directed in writing to the District by end of day Thursday February 14<sup>th</sup>, 2019. Questions received after this time may not be answered.

#### DRAWINGS & SPECIFICATIONS

ITEM NO. 1.5: PAVING REPLACEMENT EXTENTS  
Revise: View 5/A7.01 and view 6/A7.01  
Add: Keynote 18 on view 5/A7.01.


#### ATTACHMENTS

##### Drawings

*Note: Addendum 1 items identified as "A"*

AD1-A7.01a


AD1-A7.01b




**5 ENLARGED DEMO PLAN - DROP-OFF ZONE**  
**SCALE: 1/16" = 1'-0"**


**NEW SITE PLAN KEYNOTES**

**A** 18 REMOVE (E) SIDEWALK TO NEAREST JOINT, V.I.F.

|   |   |       |
|---|---|-------|
|  | <b>GUY EMANUELE JR. ELEMENTARY SCHOOL<br/>         DROP-OFF ZONE</b><br>New Haven Unified School District |       |
|   | FILE NO.: <b>1-H25</b>  | SHEET |
| APPL NO.: <b>01-117731</b>  | REF. SHEET A7.01  |       |
| JOB NO.: <b>2018003</b>   | <b>AD1-A7.01a</b>   |       |
| DATE <b>02/14/2019</b>  |   |       |
| 387 S. 1st Street, Suite 300<br>San Jose, CA., 95113                                | tel: (408) 300 - 5160<br>fax: (408) 300 - 5121  |       |



**6 ENLARGED NEW PLAN - DROP-OFF ZONE**  
**SCALE: 1/16" = 1'-0"**

|   |  |   |                   |
|---|--|---|-------------------|
|  |  | <b>GUY EMANUELE JR. ELEMENTARY SCHOOL<br/>         DROP-OFF ZONE</b><br>New Haven Unified School District |                   |
|   |  | FILE NO.: <b>1-H25</b>  | SHEET             |
| 387 S. 1st Street, Suite 300<br>San Jose, CA., 95113                                |  | APPL NO.: <b>01-117731</b>  | REF. SHEET A7.01  |
| tel: (408) 300 - 5160<br>fax: (408) 300 - 5121                                      |  | JOB NO. <b>2018003</b>  | <b>AD1-A7.01b</b> |
|   |  | DATE <b>02/14/2019</b>  |                   |