

**Hardin Park  
Optimist Pavilion**

**602 Crescent Street**

**Town Administrator Todd Smith**

**Assessment October 23, 2018**



## **LOCATION SUMMARY**

A sixty-five acre park that features an Olympic-sized swimming pool with attached bathhouse, 2 playgrounds, fishing pond, 6 covered pavilions, picnic tables, 3 baseball fields, 2 softball fields, 4 tennis courts, outdoor basketball court, a skatepark, and a walking track/trail. The park also houses the maintenance shop and staff. The maintenance area is comprised of two office buildings, 2 garages, and a storage facility.

### **Responsible for Hardin Park ADA Transition Plan Section**

Director Butch Patterson – 423-638-3143 / [bpatterson@greenevilletn.gov](mailto:bpatterson@greenevilletn.gov)

Office Manager/Program Supervisor Lisa Scott Fisher – 423-638-3143 / [lfisher@greenevilletn.gov](mailto:lfisher@greenevilletn.gov)

Maintenance Director John Darnell – 423-823-0720 / [jdarnell@greenevilletn.gov](mailto:jdarnell@greenevilletn.gov)

---

# ADA Checklist for Existing Facilities

---

Based on the 2010 ADA Standards for Accessible Design



**Project: ADA Assessment Greeneville TN**

---

**Building: Hardin Park Optimist Pavilion**

---

**Location: 602 Crescent drive**

---

**Date: Oct 2, 2018**

---

**Surveyors: Dave Wright, Gail Stacy, Caroline Miller**

---

**Contact Information: 423-525-5093**

---


---

Priority 1 – Approach & Entrance			Comments	Possible Solutions
----------------------------------	--	--	----------	--------------------

<b>1.1</b> Is there at least one route from site arrival points (parking, passenger loading zones, public sidewalks and public transportation stops) that does not require the use of stairs? [See 2010 ADA Standards for Accessible Design – 206.2.1]	Yes  If yes, location of route:		Photo #:	
--	---------------------------------------	--	----------	--

<b>Parking</b> Accessible parking spaces should be identified by size, access aisle and signage.				
--	--	--	--	--

<b>1.2</b> If parking is provided for the public, are an adequate number of accessible spaces provided? [208.2]	No spaces provided  Total #: 22 Accessible #: 0	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="padding: 5px;">Total Spaces</th> <th style="padding: 5px;">Accessible Spaces</th> </tr> </thead> <tbody> <tr> <td style="padding: 5px;">1 - 25</td> <td style="padding: 5px;">1</td> </tr> <tr> <td style="padding: 5px;">26 - 50</td> <td style="padding: 5px;">2</td> </tr> <tr> <td style="padding: 5px;">51 - 75</td> <td style="padding: 5px;">3</td> </tr> <tr> <td style="padding: 5px;">76 - 100</td> <td style="padding: 5px;">4</td> </tr> <tr> <td colspan="2" style="padding: 5px;">100+ see 2010 Standards 208.2</td> </tr> </tbody> </table>	Total Spaces	Accessible Spaces	1 - 25	1	26 - 50	2	51 - 75	3	76 - 100	4	100+ see 2010 Standards 208.2			<ul style="list-style-type: none"> <li>• Reconfigure by repainting lines</li> </ul> Budget Year: 2020  Cost: \$250
Total Spaces	Accessible Spaces															
1 - 25	1															
26 - 50	2															
51 - 75	3															
76 - 100	4															
100+ see 2010 Standards 208.2																

<b>1.9</b> Do the access aisles adjoin an accessible route? [502.3]	No		Photo #:	<ul style="list-style-type: none"> <li>• Create accessible route</li> <li>• Relocate accessible space</li> <li>•</li> </ul> Budget Year: 2020  Cost: \$250
---	----	--	----------	--

**Entrance**

**1.37** Is the main entrance accessible?

No

Photo #:

- Redesign to make it accessible
- Ref to 1.9

**Seating: At dining surfaces (restaurants, cafeterias, bars, etc.) and non-employee work surfaces (libraries, conference rooms, etc.)**

**2.64** Are at least 5%, but no fewer than one, of seating and standing spaces accessible for people who use wheelchairs? [226.1]

No

Total #:

Wheelchair #: 0

Photo #:

- Alter to provide accessible spaces
  - Add ADA compliant picnic table
- Budget Year: 2021  
Cost: \$1,000

**2.65** Is there a route at least 36 inches wide to accessible seating? [403.5.1]

Yes

Measurement:



Photo #:

