



**Nampa School District No. 131  
Smart Uninterruptible Power Supplies RFP  
Addendum #1—Questions & Clarifications**

As provided for in Section 2 of the General Proposal Conditions & Requirements for the Smart Uninterruptible Power Supplies Request for Proposal due to the District on November 27, 2018, the following specification updates and clarifications will supersede prior specifications or provide additional information as stated below.

---

**Re: UPS Required minimum run time**

**11/8/2018**

**Q:** Your UPS RFP specifies “nominal runtime on battery backup 165 minutes or greater” (Section 2 of Bid Specifications & Requirements) but later in that same section refers to the “required two-hour minimum run time.” Can you clarify which of these run time measures are the required minimum?

**A:** Given the discrepancy in run time requested and in consideration of efforts already made in preparing proposals, we have determined that the lesser of the two stated requests—“two hour run time”—will be the minimum requirement.

---

*Last updated: November 8, 2018*

*Inspiring Excellence — Every Child, Every Day*

619 S. Canyon St. Nampa, ID 83686  
www.nsd131.org

