



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Mass J/H

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 08/09/2016 12:30
Reported: 08/29/2016 21:24

Analytical Testing Parameters

Client Sample ID: 6-1
Lab Sample ID: J6H0735-01
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.015	0.015	0.0010	mg/L	G	08/24/16 1447	08/24/16 1721

Analytical Testing Parameters

Client Sample ID: 6-2
Lab Sample ID: J6H0735-02
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0013	0.015	0.0010	mg/L		08/24/16 1447	08/24/16 1722

Analytical Testing Parameters

Client Sample ID: 19-1
Lab Sample ID: J6H0735-03
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0049	0.015	0.0010	mg/L		08/24/16 1447	08/24/16 1724



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 19-2
Lab Sample ID: J6H0735-04
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0073, 0.015, 0.0010, mg/L, 08/24/16 1447, 08/24/16 1725

Analytical Testing Parameters

Client Sample ID: 4-1
Lab Sample ID: J6H0735-05
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0041, 0.015, 0.0010, mg/L, 08/24/16 1447, 08/24/16 1727

Analytical Testing Parameters

Client Sample ID: 4-2
Lab Sample ID: J6H0735-06
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0042, 0.015, 0.0010, mg/L, 08/24/16 1447, 08/24/16 1734



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 22-1
Lab Sample ID: J6H0735-07
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0083, 0.015, 0.0010, mg/L, 08/24/16 1447, 08/24/16 1736

Analytical Testing Parameters

Client Sample ID: 22-2
Lab Sample ID: J6H0735-08
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0050, 0.015, 0.0010, mg/L, 08/24/16 1447, 08/24/16 1737

Analytical Testing Parameters

Client Sample ID: 14-1
Lab Sample ID: J6H0735-09
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0021, 0.015, 0.0010, mg/L, 08/24/16 1447, 08/24/16 1739



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 14-2
Lab Sample ID: J6H0735-10
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0036, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1741

Analytical Testing Parameters

Client Sample ID: 11-1
Lab Sample ID: J6H0735-11
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.013, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1742

Analytical Testing Parameters

Client Sample ID: 11-2
Lab Sample ID: J6H0735-12
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.010, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1744



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 17-1
Lab Sample ID: J6H0735-13
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0095, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1745

Analytical Testing Parameters

Client Sample ID: 17-2
Lab Sample ID: J6H0735-14
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.053, 0.015, 0.0010, mg/L, G, 08/24/16 1450, 08/24/16 1750

Analytical Testing Parameters

Client Sample ID: 18-1
Lab Sample ID: J6H0735-15
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0050, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1751



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 18-2
Lab Sample ID: J6H0735-16
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0046, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1756

Analytical Testing Parameters

Client Sample ID: 5-1
Lab Sample ID: J6H0735-17
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0079, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1757

Analytical Testing Parameters

Client Sample ID: 5-2
Lab Sample ID: J6H0735-18
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0013, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1759



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 9-1
Lab Sample ID: J6H0735-19
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.036, 0.015, 0.0010, mg/L, G, 08/24/16 1450, 08/24/16 1801

Analytical Testing Parameters

Client Sample ID: 9-2
Lab Sample ID: J6H0735-20
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0060, 0.015, 0.0010, mg/L, , 08/24/16 1450, 08/24/16 1802

Analytical Testing Parameters

Client Sample ID: 2-1
Lab Sample ID: J6H0735-21
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.078, 0.015, 0.0050, mg/L, G, 08/25/16 0822, 08/25/16 1441



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 2-2
Lab Sample ID: J6H0735-22
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0078, 0.015, 0.0050, mg/L, 08/25/16 0822, 08/25/16 1445

Analytical Testing Parameters

Client Sample ID: 3-1
Lab Sample ID: J6H0735-23
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0043, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1804

Analytical Testing Parameters

Client Sample ID: 3-2
Lab Sample ID: J6H0735-24
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0026, 0.015, 0.0010, mg/L, 08/24/16 1450, 08/24/16 1808



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 13-1
Lab Sample ID: J6H0735-25
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.026, 0.015, 0.0010, mg/L, G, 08/24/16 1540, 08/26/16 1427

Analytical Testing Parameters

Client Sample ID: 13-2
Lab Sample ID: J6H0735-26
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0019, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1431

Analytical Testing Parameters

Client Sample ID: 12-1
Lab Sample ID: J6H0735-27
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.024, 0.015, 0.0010, mg/L, G, 08/24/16 1540, 08/26/16 1433



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 12-2
Lab Sample ID: J6H0735-28
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0014, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1434.

Analytical Testing Parameters

Client Sample ID: 20-1
Lab Sample ID: J6H0735-29
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0059, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1436.

Analytical Testing Parameters

Client Sample ID: 20-2
Lab Sample ID: J6H0735-30
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.027, 0.015, 0.0010, mg/L, G, 08/24/16 1540, 08/26/16 1437.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 1-1
Lab Sample ID: J6H0735-31
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.012, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1439

Analytical Testing Parameters

Client Sample ID: 1-2
Lab Sample ID: J6H0735-32
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0063, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1441

Analytical Testing Parameters

Client Sample ID: 10-1
Lab Sample ID: J6H0735-33
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.032, 0.015, 0.0010, mg/L, G, 08/24/16 1540, 08/26/16 1445



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 10-2
Lab Sample ID: J6H0735-34
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0039, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1447

Analytical Testing Parameters

Client Sample ID: 8-1
Lab Sample ID: J6H0735-35
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0080, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1448

Analytical Testing Parameters

Client Sample ID: 8-2
Lab Sample ID: J6H0735-36
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0037, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1453



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 7-1
Lab Sample ID: J6H0735-37
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0041, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1454

Analytical Testing Parameters

Client Sample ID: 7-2
Lab Sample ID: J6H0735-38
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0020, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1456

Analytical Testing Parameters

Client Sample ID: 21-1
Lab Sample ID: J6H0735-39
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.49, 0.015, 0.0050, mg/L, G, 08/25/16 0822, 08/25/16 1449



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6H0735

Analytical Testing Parameters

Client Sample ID: 21-2
Lab Sample ID: J6H0735-40
Sample Type: Grab

Collected By: RF/LS-Client
Collection Date: 08/04/16
Collection Time: 08:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.010, 0.015, 0.0010, mg/L, 08/24/16 1540, 08/26/16 1457

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
PQL: Practical Quantitation Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, Item, Yes. Items include Custody Seals Intact, COC/Labels Agree, Received on Ice.

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863
New York State Department of Health
Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Handwritten signature of Michael Fifield

Michael Fifield
Division Manager
08/29/2016 21:24

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

MA-30

5/14

MNY Workorder #

Client Information			Billing/Invoice:		
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES				
Address:	20104 NYS Route 3 Watertown, NY 13601				
Contact:	Ray Filley				
Phone:	315-779-7054				
Project:	Lead Testing				
Quote ID:		PO#:			
Rush FAT Bur. Days:	2-5	5-7	7-10	Date Req.:	
Release to DOH: Yes					
Email Results: Yes	rifilley@boces.com / rfilley@boces.com				
Fax Results: Yes					

Sample Information			Analysis Requested			Receiving Info (Lab Use Only)		
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Accepted?	Container Material	Container Size (in MI)
1 G-1	8/4	8:03	RF	200.8 Lead		YES		
2 G-2		8:04						
3 19-1		8:33						
4 19-2		8:34						
5 4-1		8:01						
6 4-2		8:02						
7 22-1		8:35						
8 22-2		8:36						

Print Name and Company	Signature	Date/Time	Comments
Sampled: Ray Filley LINDA JUNG	<i>Ray Filley</i>	8/5 1300	
Received: David Thom 95	<i>David Thom</i>	8/9/16 12:30	
Received:	<i>Juniper Walker</i>	8/9/16 12:30	
Received:			
Received:			
Received:			



J6H0735

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this notice.

MASS 5/4 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	3 2-5 5-7 7-10	Date Req:				Accepted?	YES NO
Release to DOH: Yes						Container Material	
Email Results: Yes	rfilley@booces.com					Container Size (in MI)	
Fax Results: Yes	ffhack@booces.com					Preservative	
Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial	Type			
1 14-1	8/4	8:24	RF				
2 14-2		8:26					
3 11-1		8:27					
4 11-2		8:23					
5 17-1		8:28					
6 17-2		8:29					
7 18-1		8:30					
8 18-2		8:31					
Sampled: Ray Filley LINDA SHAW		Signature: [Signature]		Date/Time: 8/5 1300		Comments	
Received: David Thomas		Signature: [Signature]		Date/Time: 8/9/14 1230			
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

MASS
 MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested						Receiving Info (Lab Use Only)				
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES Address: 20104 NYS Route 3 Watertown, NY 13601 Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing Quote ID: PO#:			Rush TAT Bur. Days: 2-5 5-7 7-10 Date Req:			Number of Containers for Analysis Requested						Ice: YES NO Cooler: YES NO Sample Temp: YES NO Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material Container Size (in MI) Preservative				
Sample Information			Matrix			Number of Containers for Analysis Requested						Comments/Field Data				
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested						Comments					
1 S-1	8/4	8:05	RFS													
2 S-2		8:06														
3 Q-1		8:20														
4 Q-2		8:21														
5 Z-1		8:09														
6 Z-2		8:10														
7 3-1		8:05														
8 3-2		8:06														
Sampled: Ray Filley Received: David Thomas			Signature: <i>[Signature]</i> Date/Time: 8/15/2008													
Received:																
Received:																
Received:																
Received:																

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:	PO#:					Dropoff:	C W
Rush TAT Bur. Days: <2 2-5 5-7 7-10	Date Req.:					Accepted?	YES NO
Relays to DOH: Yes						Container Material	
Email Results: Yes	rfilley@boCES.com / fhawk@boCES.com					Container size (in MI)	
Fax Results: Yes						Preservative	
Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial	Type			
1 13-1	8/4	8:22	RF LS				
2 13-2		8:23					
3 12-1		8:21					
4 12-2		8:22					
5 20-1		8:16					
6 20-2		8:17					
7 1-1		8:08					
8 1-2		8:09					
Print Name and Company		Signature		Date/Time		Comments	
Sampled: Ray Filley LINCOLN SHAW		Ray Filley		8/5 1300			
Received: Dan J Thomas		Dan J Thomas		8/2/16 1230			
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this notice.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

3821 Buick Drive
Cortland NY 13045
Phone: (607) 753-3403 Fax: (607) 753-3415
NY #10795, EPA #NY000935

Samples must be returned on ice

MASS 5/4 MNY Workorder #

Client Information				Billing/Invoice:			
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES							
Address: 20104 NYS Route 3 Watertown, NY 13601							
Contact: Ray Filley							
Phone: 315-779-7054							
Project: Lead Testing							
Quote ID: PO#:							
Rush TAT Bus. Days: <2 2-5 5-7 7-10				Date Req.:			
Release to DOH: Yes							
Email Results: Yes				Email: <u>rfilley@boces.com</u> / <u>ffhack@boces.com</u>			
Fax Results: Yes							
Sample Information							
Description/Location		Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	
1	10-1	8/4	8:19	RF			
2	10-2		8:20				
3	8-1		8:16a				
4	8-2		8:17				
5	7-1		8:12				
6	7-2		8:13				
7	21-1		8:10				
8	21-2		8:11				
				Matrix Type		Comments/Field Data	
				HNO3			
				250			
				P			
				200.8 Lead			
				Accepted?		YES NO	
				Container Material			
				Container Size (in MI)			
				Preservative			
				Dropoff:		C W	
				Pickup:		YES NO	
				Cooler Seal:		YES NO	
				Sample Temp:			
				Cooler:		YES NO	
				Ice:		YES NO	
				Receiving Info (Lab Use Only)			

Print Name and Company	Signature	Date/Time	Comments
Sampled: Ray Filley LINDA STARBU		8/5 13:00	
Received: David Thomas		8/2/16 12:30	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.