



*Excellence Delivered **As Promised***

May 9, 2019

Dr. Wesley W. Shipley, Superintendent
Mars Area School District
545 Route 228
Mars, PA 16046

Subject: *Mars Area School District
Potable Water Lead Testing Results*

Dear Dr. Shipley:

Gannett Fleming is pleased to submit the drinking water fountain lead testing results for the Mars Area School District's High School, Intermediate School, Middle School, Centennial School, Elementary School and Primary School.

These facilities receive their water from the Municipal Water Authority of Adams Township which is the public water supplier for the Mars area.

Sampling was conducted on April 25th and 26th, 2019 at five locations at the Elementary School and four locations at the High School, Middle School, Primary School and Centennial School.

Sampling was conducted by Gannett Fleming personnel following USEPA recommendations for conducting lead sampling in schools. These requirements include collecting 250 milliliter "first draw" samples. That is, sampling of the fixtures was conducted after they had been allowed to sit stagnant overnight. Sampling was conducted prior to the start of the school day before the buildings were occupied. Each fixture was tagged and taken out of service so that it was not mistakenly used prior to the collection of the first draw sample.

Twenty-one samples were collected from the five buildings. Of those samples, none exceeded the PA DEP's 0.015 mg/L Action Level for lead. In fact, only one sample showed a detectable level of lead. The laboratory's reporting limit for Lead analyses is 0.001 mg/L. The sample from the fountain located on the first floor of the High School close to Room 152 showed a lead level of 0.001mg/L, or just over the reporting limit.

Please find attached the laboratory reports for this testing as well as a summary table listing all of the sampling results.

Gannett Fleming, Inc.

Foster Plaza 8 • Suite 400 • 730 Holiday Drive • Pittsburgh, PA 15220

t: 412-922-5575 • f: 412-922-3717

www.gannettfleming.com

Gannett Fleming

Dr. Wesley W. Shipley, Superintendent
Mars Area School District

May 9, 2019
Page 2 of 2

Gannett would like to thank the School District's administrative and maintenance staff for their assistance in completing this project. Please feel free to contact us if you have any questions or comments.

Sincerely,

GANNETT FLEMING, INC.


ERIC T. BUZZA
Project Manager

Attachments

cc: Randy Smith, Mars School District
GF File

**Mars Area School District
Lead Sampling Results
April 25 & 26, 2019**

**PA DEP Lead Action Level -
0.015 mg/L**

Parameter	Building	Location	Sample Date	Result (mg/L)
Lead	High School	Fountain Room 235	4/25/2019	<0.001
Lead	High School	Fountain Room 152	4/25/2019	0.001
Lead	High School	Fountain Room 101	4/25/2019	<0.001
Lead	High School	Fountain Room 25	4/25/2019	<0.001
Lead	Middle School	Gym Fountain	4/25/2019	<0.001
Lead	Middle School	Chorus Room Fountain	4/25/2019	<0.001
Lead	Middle School	Fountain Room 125	4/25/2019	<0.001
Lead	Middle School	Fountain Room 108	4/25/2019	<0.001
Lead	Centennial School	Guidance Fountain	4/26/2019	<0.001
Lead	Centennial School	Fountain Room 305	4/26/2019	<0.001
Lead	Centennial School	Fountain Room 405	4/26/2019	<0.001
Lead	Centennial School	Fountain Room 207	4/26/2019	<0.001
Lead	Elementary School	Nurse Fountain	4/26/2019	<0.001
Lead	Elementary School	C-122 Fountain	4/26/2019	<0.001
Lead	Elementary School	C-021 Fountain	4/26/2019	<0.001
Lead	Elementary School	C-041 Fountain	4/26/2019	<0.001
Lead	Elementary School	Gym Fountain	4/26/2019	<0.001
Lead	Primary School	School Admin Fountain	4/26/2019	<0.001
Lead	Primary School	Cafeteria Fountain	4/26/2019	<0.001
Lead	Primary School	Fountain Room 107	4/26/2019	<0.001
Lead	Primary School	Fountain Room 117	4/26/2019	<0.001



Microbac Laboratories Inc., Pittsburgh Division
CERTIFICATE OF ANALYSIS

9044001

GANNETT FLEMING, INC.

Project Name: Mars Area School District

ERIC BUZZA
 FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE
 PITTSBURGH, PA 15220

Project / PO Number: N/A
 Received: 04/25/2019
 Reported: 05/07/2019

Analytical Testing Parameters

Client Sample ID: HS Fountain Rm 235	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/25/2019 6:05
Lab Sample ID: 9044001-01	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		04/30/19 1030	05/01/19 1203	JYH

Client Sample ID: HS Fountain Rm 152	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 04/25/2019 6:10
Lab Sample ID: 9044001-02	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.001		0.001	mg/L		04/30/19 1030	05/01/19 1104	JYH

Client Sample ID: HS Fountain Rm 101	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/25/2019 6:13
Lab Sample ID: 9044001-03	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		04/30/19 1030	05/01/19 1206	JYH

Client Sample ID: HS Fountain Rm 25	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/25/2019 6:17
Lab Sample ID: 9044001-04	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		04/30/19 1030	05/01/19 1216	JYH



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9044001

Client Sample ID: MS Gym Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/25/2019 6:28
Lab Sample ID: 9044001-05	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		04/30/19 1030	05/01/19 1219	JYH

Client Sample ID: MS Chorus Rm Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/25/2019 6:30
Lab Sample ID: 9044001-06	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		04/30/19 1030	05/01/19 1234	JYH

Client Sample ID: MS Rm 125 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/25/2019 6:32
Lab Sample ID: 9044001-07	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		04/30/19 1030	05/01/19 1238	JYH

Client Sample ID: MS Rm 108 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/25/2019 6:35
Lab Sample ID: 9044001-08	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		04/30/19 1030	05/01/19 1241	JYH

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9044001

Project Requested Certification(s)

Microbac Laboratories Inc., - Marietta, OH
68-01670

PA Department of Environmental Protection

Microbac Laboratories Inc., Pittsburgh Division
02-00257

PA Department of Environmental Protection
PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Carolyn Vollentine
Service Center Manager
Reported: 05/07/2019 10:27

Microbac Laboratories, Inc.

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com

9044001
CHAIN OF CUSTODY RECORD

Number
 Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID 1246 58°C

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

(needed by)

Report Type

[] Results Only [] Level 1 [] Level 2 [] Level 3 [] Level 4 [] EDD

[] Mail [] Fax [] e-mail (address)

Send Report via: [] Mail [] Fax Pre-mail (address) or e-mail (address) *Send invoice via:*

Compliance Monitoring? [] Yes [] No

PO No.:

Project: *Mares Area School District*

Sampler Phone No.:

Signature:

Sampled by (PRINT):

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HMC3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS



Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional
1	HS Fountain Rm 230	4/25/19	6:05	1	DN			
2	HS Fountain Rm 152		6:10					
3	HS Fountain Rm 101		6:13					
4	HS Fountain Rm 25		6:17					
5	MIS Gym Fountain		6:28					
6	MIS Chorus Rm Fountain		6:50					
7	MIS Rm 125 Fountain		6:52					
8	MIS Rm 108 Fountain		6:55					

Handwritten:
 HNO3 preserved
 Date: 4/25/19
 Time: 1:11
 Initials: JLV

Possible Hazard Identification [] Hazardous [] Non-Hazardous [] Radioactive [] Sample Disposition [] Dispose as appropriate [] Return [] Archive

Relinquished By (signature) *[Signature]* Date/Time *4/25/19*
 Relinquished By (signature) *[Signature]* Date/Time *4/25/19*

Received By (signature) *[Signature]* Date/Time *4-25-19 805*
 Received By (signature) *[Signature]* Date/Time *4-25-19 805*



Microbac Laboratories Inc., Pittsburgh Division
CERTIFICATE OF ANALYSIS

9044162

GANNETT FLEMING, INC.

Project Name: Mars Area School District

ERIC BUZZA
 FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE
 PITTSBURGH, PA 15220

Project / PO Number: N/A
 Received: 04/26/2019
 Reported: 05/07/2019

Analytical Testing Parameters

Client Sample ID: Primary School Admin Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:10
Lab Sample ID: 9044162-01	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1733	JYH

Client Sample ID: Primary School Cafeteria Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:13
Lab Sample ID: 9044162-02	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1737	JYH

Client Sample ID: Primary School Rm 107 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:15
Lab Sample ID: 9044162-03	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1740	JYH

Client Sample ID: Primary School Rm 117 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:16
Lab Sample ID: 9044162-04	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1743	JYH



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9044162

Client Sample ID: Elementary Nurse Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:21
Lab Sample ID: 9044162-05	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1746	JYH

Client Sample ID: Elementary C-122 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:23
Lab Sample ID: 9044162-06	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1750	JYH

Client Sample ID: Elementary C-021 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:28
Lab Sample ID: 9044162-07	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1756	JYH

Client Sample ID: Elementary C-041 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:30
Lab Sample ID: 9044162-08	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1759	JYH



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9044162

Client Sample ID: Elementary Gym Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:32
Lab Sample ID: 9044162-09	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1809	JYH

Client Sample ID: Elementary Guidance Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:41
Lab Sample ID: 9044162-10	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1813	JYH

Client Sample ID: Centennial 305 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:44
Lab Sample ID: 9044162-11	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1816	JYH

Client Sample ID: Centennial 405 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:46
Lab Sample ID: 9044162-12	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1819	JYH



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9044162

Client Sample ID: Centennial 207 Fountain	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 04/26/2019 6:48
Lab Sample ID: 9044162-13	

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001		0.001	mg/L		05/01/19 1006	05/01/19 1822	JYH

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., - Marietta, OH
68-01670

PA Department of Environmental Protection

Microbac Laboratories Inc., Pittsburgh Division
02-00257

PA Department of Environmental Protection
PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Carolyn M. Vollentine

Carolyn Vollentine
Service Center Manager
Reported: 05/07/2019 09:54



CHAIN OF CUSTODY

Put bar code here

Microbac Erie Division
1962 Wager Road
Erie, PA 16509

Page 1 of 2

Work Order #.

Client /Company Name: Erasmus Erasmus Area School Dist		Contact Name: Eric Buza		Analyses									
Address: Postar Plaza 8 Suite 400 730 Holiday Dr		Bill To/PO#:											
City/State/Zip: Pittsburgh PA 15220		Potential Hazards: Non-Hazard <input checked="" type="checkbox"/> Hazard <input type="checkbox"/> Radioactive <input type="checkbox"/>											
Phone: 412 922 5575		Disposal: Dispose of <input checked="" type="checkbox"/> Return <input type="checkbox"/> Retain <input type="checkbox"/>											
Project Name/ID: erasmus@erast.com		Compliance Sample: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>											
Sampled By: Eric Buza		Due Date:											
Shipped By:		Tracking #:											
Type Code: G-Grab C-Composite		Comp. Start:		Monitoring Period:									
Matrix Code: DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other		Comp. Stop:		Preservatives									
Sample Identification		Date Taken	Time Taken	Type G C	Matrix	Tot. # Cont.	None	HNO3	H2SO4	NaOH	HCl	Thio	Other
Primary School Admin Fountain	4/26	610			DW	1							
Primary School Catholics Fountain		613											
Primary School Rm 107 Fountain		615											
Primary School Rm 117 Fountain		616											
Elementary Marsie Fountain		621											
Elementary C-123 Fountain		623											



9 0 4 4 1 6 2
GANNETT FLEMING, INC.
PM: Carolyn Volentine

HNO3 Preserved
Date: 4/26/19
Time: 1500
Initials: RIM

Lead

Relinquished By: R. Byrd	Date/Time: 4/26/19	Received By: John Quail	Date/Time: 4/26/19	Temp: 14.05 °C
Relinquished By:	Date/Time:	Received By:	Date/Time:	Iced: Y N
Relinquished By:	Date/Time:	Received By:	Date/Time:	Intact: Y N
Relinquished By:	Date/Time:	Received By:	Date/Time:	



CHAIN OF CUSTODY

Put bar code here

Microbac Erie Division
1962 Wager Road
Erie, PA 16509

Page 1 of 2

Work Order #.

Client /Company Name: <u>BASED GE Mars Area School Dist</u>		Contact Name: <u>Eric Buza</u>		Analyses									
Address: <u>Foster Plaza 8 Suite 400 730 Holiday Dr</u>		Bill To/PO#:											
City/State/Zip: <u>Pittsburgh PA 15120</u>		Potential Hazards: Non-Hazard <input checked="" type="checkbox"/> Hazard <input type="checkbox"/> Radioactive <input type="checkbox"/>											
Phone: <u>412 972 5575</u>		Disposal: Dispose of <input checked="" type="checkbox"/> Return <input type="checkbox"/> Retain <input type="checkbox"/>											
Project Name/ID: <u>Eric Buza</u>		Compliance Sample: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>											
Due Date:		State:											
Shipped By: <u>Eric Buza</u>		Tracking #:											
Type Code: G-Grab C-Composite		Comp. Start:		Monitoring Period:									
Matrix Code: DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other		Comp. Stop:											
Sample Identification		Date Taken	Time Taken	Type G C	Matrix	Tot. # Cont.	None	HNO3	H2SO4	NaOH	HCl	Thio	Other
<u>Elementary Fountain</u>	<u>4/26</u>	<u>628</u>	<u>628</u>	<input checked="" type="checkbox"/>	<u>DW</u>	<u>1</u>	<input checked="" type="checkbox"/>						
<u>Elementary Fountain</u>		<u>630</u>											
<u>Elementary Fountain</u>		<u>632</u>											
<u>Centennial Fountain</u>		<u>641</u>											
<u>Centennial Fountain</u>		<u>644</u>											
<u>Centennial Fountain</u>		<u>646</u>											
Instructions/Comments: <u>207 Fountain</u>													
Relinquished By: <u>[Signature]</u>		Date/Time: <u>4/26/19 1405</u>		Received By: <u>[Signature]</u>		Date/Time: <u>4/26/19 1405</u>		Temp <u>10.4 C</u>		Iced: <input checked="" type="checkbox"/> N		Intact: <input checked="" type="checkbox"/> N	
Relinquished By:		Date/Time:		Received By:		Date/Time:							
Relinquished By:		Date/Time:		Received By:		Date/Time:							
Relinquished By:		Date/Time:		Received By:		Date/Time:							



GANNETT FLEMING, INC.
PM: Carolyn Volentine

HNO3 Preserved
Date: 4/26/19
Time: 15:00
Initials: RM

Lead to report

CAHB