

Ginny Kidwell Amphitheater

Tusculum View Extension

Town Administrator Todd Smith

Assessment October 23, 2018



LOCATION SUMMARY

This portion of Dogwood Park contains a 200-seat amphitheater, a footbridge, and a wetlands natural habitat pond. The park is home to the Recreation Department's "Concert in the Park" series each summer and serves as a teaching location for teachers and students from neighboring Tusculum View Elementary School.

Responsible for Ginny Kidwell Amphitheater ADA Transition Plan Section

Director Butch Patterson – 423-638-3143 / bpatterson@greenevilletn.gov

Office Manager/Program Supervisor Lisa Scott Fisher – 423-638-3143 / lfisher@greenevilletn.gov

Maintenance Supervisor John Darnell – 423-823-0720 / jdarnell@greenevilletn.gov

ADA Checklist for Existing Facilities

Priority 1 – Approach & Entrance

Based on the 2010 ADA Standards for Accessible Design



Project: ADA Assessment Greeneville, TN

Building: Ginny Kidwell Amphitheater

Location: 1725 Lafayette Street

Date: Oct. 10, 2018

Surveyors: Dave Wright, Gail Stacy, Caroline Miller

Contact Information

An accessible route from site arrival points and an accessible entrance should be provided for everyone.

Priority 1 – Approach & Entrance			Comments	Possible Solutions												
1.1	Is there at least one route from site arrival points (parking, passenger loading zones, public sidewalks and public transportation stops) that does not require the use of stairs? [See 2010 ADA Standards for Accessible Design – 206.2.1]	No - Parking provided in school parking lot does not provide access	Photo #:	<ul style="list-style-type: none"> Design accessible route 												
1.2	If parking is provided for the public, are an adequate number of accessible spaces provided? [208.2]	<p>No</p> <p>Total #: 0</p> <p>Accessible #: 0</p> <table border="1"> <thead> <tr> <th>Total Spaces</th> <th>Accessible Spaces</th> </tr> </thead> <tbody> <tr> <td>1 - 25</td> <td>1</td> </tr> <tr> <td>26 - 50</td> <td>2</td> </tr> <tr> <td>51 - 75</td> <td>3</td> </tr> <tr> <td>76 - 100</td> <td>4</td> </tr> <tr> <td colspan="2">100+ see 2010 Standards 208.2</td> </tr> </tbody> </table>	Total Spaces	Accessible Spaces	1 - 25	1	26 - 50	2	51 - 75	3	76 - 100	4	100+ see 2010 Standards 208.2		Photo #:	<ul style="list-style-type: none"> Design and install accessible parking spaces
Total Spaces	Accessible Spaces															
1 - 25	1															
26 - 50	2															
51 - 75	3															
76 - 100	4															
100+ see 2010 Standards 208.2																
Exterior Accessible Route																
1.13	Is the route stable, firm and slip-resistant? [302.1]	No accessible route	 <p>Photo #:</p>	<ul style="list-style-type: none"> Design and install accessible route 												

Entrance

1.37 Is the main entrance accessible?

No

Photo #:

- Redesign to make it accessible
-
-

1.38 If the main entrance is not accessible, is there an alternative accessible entrance?

No

NA




Photo #:

- Designate an entrance and make it accessible
- Ensure that accessible entrance can be used independently and during the same hours as the main entrance
-

Can the alternative accessible entrance be used independently and during the same hours as the main entrance?

1.39 Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance?
[216.6]

No



Photo #:

- Install signs
- Install signs on route before people get to inaccessible entrances so that people do not have to turn around and retrace route
-

Seating: Assembly Areas – theaters, auditoriums, stadiums, theater style classrooms, etc.

2.52 Are an adequate number of wheelchair spaces provided? [221.2.1]

No
Total #: +/-400
Wheelchair #: 0

# of Seats	Wheelchair Spaces
4 - 25	1
26 - 50	2
51 - 150	4
151 - 300	5
300+ see 2010 Standards 221.2.1.	



Photo #:

- Reconfigure to add wheelchair spaces
-
-

Priority 3 – Toilet Rooms

3.1 If toilet rooms are available to the public, is at least one toilet room accessible? (Either one for each sex, or one unisex.)

Note: If toilet rooms are chiefly for children, e.g., in elementary schools and day care centers, use the children’s specifications in Toilets - 604.1, 604.8, 604.9, 609.4 and Lavatories and Sinks – 606.2.

No
Port-o-potties are provided but no ADA port-o-potties

Comments

Possible Solutions



Photo #:

- Add ADA port-o-potty