

## **SECTION 26 51 00 - INTERIOR LIGHTING**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 16 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. This Section includes the following:
  1. LED Flat panel/retrofit kits.
  2. LED wrap around fixtures.
  3. LED high bay fixtures
  4. LED lamps (replacement only)
  5. Emergency lighting units.

#### **1.3 DEFINITIONS**

- A. CRI: Color-rendering index.
- B. CU: Coefficient of utilization.
- C. HID: High-intensity discharge.
- D. LER: Luminaire efficacy rating.
- E. Luminaire: Complete lighting fixture, including ballast housing if provided.
- F. RCR: Room cavity ratio.

#### **1.4 SUBMITTALS**

- A. Product Data: For each type of lighting fixture, arranged in order of fixture designation. Include data on features, accessories, finishes, and the following:
  1. Physical description of lighting fixture including dimensions.
  2. Emergency lighting units including battery and charger.
  3. Ballast. For LED Lamp replacements, provide verification of ballast/driver compatibility with replacement LED Lamp; provide product data for ballast/driver replacement product for incompatible ballast-lamp configurations for all areas in scope of work.
  4. Energy-efficiency data.
  5. Life, output, and energy-efficiency data for lamps.

6. Photometric data, in IESNA format, based on laboratory tests of each lighting fixture type, outfitted with lamps, ballasts, and accessories identical to those indicated for the lighting fixture as applied in this Project. The following are acceptable:
  - a. For indicated fixtures, photometric data shall be certified by a qualified independent testing agency. Photometric data for remaining fixtures shall be certified by the manufacturer.
  - b. Photometric data shall be certified by a manufacturer's laboratory with a current accreditation under the National Voluntary Laboratory Accreditation Program (NVLAP) for Energy Efficient Lighting Products.
- B. Operation and Maintenance Data: For lighting equipment and fixtures to include in emergency, operation, and maintenance manuals.
- C. Warranties: As specified in this Section.

## 1.5 QUALITY ASSURANCE

- A. Luminaire Photometric Data Testing Laboratory Qualifications: Provided by manufacturers' laboratories that are accredited under the National Volunteer Laboratory Accreditation Program for Energy Efficient Lighting Products.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Comply with NFPA 70 and CEC for the current year.
- D. FMG Compliance: Lighting fixtures for hazardous locations shall be listed and labeled for indicated class and division of hazard by FMG.
- E. All lighting fixtures shall be UL approved.

## 1.6 WARRANTY

- A. Warranty Period for LED Replacement Fixtures:
  1. Warranty Period: Five years from date of Substantial Completion. Full warranty shall apply to all components of the retrofit kit, including LED board, lamp, driver, and nonelectrical components.
- B. Warranty for LED Lamps (replacement only): Manufacturer's standard form, made out to Owner and signed by lamp manufacturer agreeing to replace lamps that fail in materials or workmanship, f.o.b. the nearest shipping point to Project site, within specified warranty period indicated below.
  1. Warranty Period: Five years from date of Substantial Completion.
- C. Warranty Period for Lighting Control System

1. Warranty Period: Five years from date of Substantial Completion. Full warranty shall apply to all components of the lighting control system, including all components address by the technical requirements.

## 1.7 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Lamps: 2 for every 100 of each type and rating installed. Furnish at least one of each type.
  2. Battery and Charger Data: 1 for each emergency lighting unit.
  3. Globes and Guards: 1 for every 20 of each type and rating installed. Furnish at least one of each type.

## PART 2 - PRODUCTS

### 2.1 INDOOR LUMINAIRE, TROFFER, INTEGRATED RETROFIT KIT

#### 1. Door Kit Type.

1. Product must be listed on the DesignLights Consortium Premium qualified products list. Linear LED retrofit kits do not qualify.
2. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Philips.
  - b. Sylvania Lighting.
  - c. Maxlite.
  - d. Lithonia Lighting.
  - e. CREE
  - f. Or District approved equal.
2. Construction: Galvanized steel and powder coated after fabrication.
3. Color: White.
4. Minimum depth: 3 inches.
5. CRI:  $\geq 80$ .
6. Driver: Internal, dimmable 0-10V
7. Size: 2 feet x 4 feet, 2 feet x 2 feet, 1 feet x 4 feet
8. Color temperature (K): 4,000K.
9. DLC listed initial output must be  $\geq 2,200$  lm and  $\leq 6,500$  lm
10.  $\geq 125$  lumens/Watt
11. 50,000 hour L70 Lumen Maintenance
12. 36,000 hour L90 Lumen Maintenance
13. Spacing Criteria from 1.0 to 2.0 in both the 0-180 degree and 90-270 degree directions.
14.  $\geq 75\%$  of lumen output in the 0-60-degree zone.

#### 2. Indoor Luminaire, Troffer, LED Flat Panel.

1. Product must be listed on the DesignLights Consortium Premium qualified products list.

2. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

- a. Philips.
- b. Sylvania Lighting.
- c. Maxlite.
- d. Lithonia Lighting.
- e. DECO Lighting.
- f. Or District approved equal.

2. Construction: Galvanized steel and powder coated after fabrication.

3. Color: White.

4. Minimum depth: 3 inches.

5. CRI:  $\geq 80$ .

6. Driver: Internal, dimmable 0-10V

7. Size: 2 feet x 4 feet, 2 feet x 2 feet, 1 feet x 4 feet

8. Color temperature (K): 4,000K.

9. DLC listed initial output must be  $\geq 2,200$  lm and  $\leq 6,500$  lm

10.  $\geq 125$  lumens/Watt

11. 50,000 hour L70 Lumen Maintenance

## 2.2 LED WRAP AROUND FIXTURES

### A. Vapor Tight Wrap Around Fixture Type.

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

- a. DECO Lighting.
- b. Lithonia.
- c. Sylvania.
- d. Maxlite
- e. RAB Lighting
- f. Or District approved equal.

2. Construction: Impact resistant Polycarbonate.

3. IP Rating:  $>65$  (dust and water)

4. Color: White.

5. Minimum depth: 3 inches.

6. CRI:  $>80$ .

7. Driver: Internal, dimmable 0-10V

8. Watts:  $<50$  watts

9. Lumens:  $>4000$  lumens.

10. Lamp: Integral LED.

11. Voltage: 120 – 277 V AC.

12. Size: 48 inches length

13. Color temperature (K): 4,000k.

### B. Wrap Around Fixture Type.

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - a. DECO Lighting.
  - b. Lithonia.
  - c. Sylvania.
  - d. Maxlite
  - e. RAB Lighting
  - f. Or District approved equal.
2. Construction: Galvanized steel and powder coated after fabrication.
3. Color: White.
4. Minimum depth: 3 inches.
5. CRI: >80.
6. Driver: Internal, dimmable 0-10V
7. Light bar: Multiple.
8. Lamp: Integral LED.
9. Voltage: 120 – 277 V AC.
10. Size: 2 feet x 4 feet, 2 feet x 2 feet, and 1 feet x 4 feet
11. >110 lumens/watt
12. Color temperature (K): 4,000k.

### 2.3 LED HIGH BAY FIXTURES

#### A. Fixture Type: LED High Bay

- a. Lithonia
- b. DECO Lighting
- c. Philips
- d. Sylvania
- e. Maxlite
- f. Columbia
- g. Or District approved equal.
2. Driver: Internal.
3. Length: Width >18”; Length >24”
4. LED Type: Integrated Diode.
5. Grade: Commercial.
6. Voltage: 120 – 277 V AC
7. Initial Lumens: >25,000
8. CRI: > 80.
9. >115 lumens/watt
10. Color temperature (K): 4,000K

#### B. Interior Pendant Type Direct/ Indirect

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Deco Lighting
  - b. Sylvania Lighting.
  - c. RAB Lighting
  - d. Lithonia Lighting
  - e. Texas Fluorescents
  - f. Or District approved equal.
2. Construction: Galvanized steel and powder coated after fabrication.
3. Color: White or silver
4. Minimum depth: 3 inches.
5. CRI: >80.
6. Driver: Internal, dimmable 0-10V
7. Voltage: 120 – 277 V AC.
8. Wattage: <50 watts 48 inch; <75 watts 96 inch
9. Lumens: 80% Direct Lighting; 20% Indirect Lighting
10. Driver: Internal
11. Size: 48 inch and 96 inch
12. Color temperature (K): 4,000k.

#### 2.4 LED LAMPS (REPLACEMENT ONLY)

##### A. Lamp Type: T8 LED

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Green Creative.
  - b. Maxlite.
  - c. ESPEN.
  - d. Sylvania Lighting.
  - e. Or District approved equal.
2. Must be DLC® listed under “Replacement Lamps (plug and play) (UL Type A) and compatible with existing ballast
3. Ballast: Instant start or programmed ballast compatible, TBD by District. Must be dimmable
4. Length: 48 inches.
5. Lamp Shape: T8.
6. Grade: Commercial.
7. Voltage: 120 – 277 V AC.
8. Initial Lumens: >1800.
9. Power: ≤ 12 W
10. CRI: ≥ 80.
11. Driver: Dimmable
12. Efficacy: ≥ 110 LPW
13. Power Factor: ≥ 0.9
14. Total Harmonic Distortion ≤ 20%

15. Color temperature (K): 4,000 K.
16. 50,000 hours L70 Lumen Maintenance

B. Lamp Type: T5 LED HE

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Green Creative
  - b. Maxlite.
  - c. Lunera.
  - d. ESPEN.
  - e. Or District approved equal.
2. Ballast: Instant start or programmed ballast compatible, TBD by District. Must be dimmable
3. Length: 48 inches.
4. Lamp Shape: T5.
5. Grade: Commercial.
6. Voltage: 120 – 277 V AC.
7. Initial Lumens: >1800.
8. Power:  $\leq 15$  W
9. CRI: > 80.

## 2.5 LED LAMPS (REPLACEMENT ONLY)

A. Lamp Type: A19-A21

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Philips
  - b. Green Creative
  - c. Maxlite
  - d. Or District approved equal.
2. Driver: Internal.
3. Length: 6 inches
4. Lamp Shape: A19; A21
5. Grade: Commercial Full Dimmable
6. Voltage: 120 – 277 V AC.
7. Initial Lumens: 800.
8. CRI: > 80.
9. Color temperature (K): 4,000k.

## 2.6 EMERGENCY LIGHTING UNITS

A. Emergency LED Ballast

Description: Self-contained units complying with UL 924, NFPA 101, NFPA 70-NED. Damp location 32°F to 122°F listed standard, provides 90 minutes of emergency power, 650 lumens minimum. Must install with illuminated test switch. 5-year warranty.

1. Battery: Sealed, maintenance-free, nickel-cadmium.
2. Charger: Fully automatic, solid-state type with sealed transfer relay.
3. Operation: Relay automatically turns lamp on when power supply circuit voltage drops to 80 percent of nominal voltage or below. Lamp automatically disconnects from battery when voltage approaches deep-discharge level. When normal voltage is restored, relay disconnects lamps from battery, and battery is automatically recharged and floated on charger.
4. Test Push Button: Push-to-test type, in unit housing, simulates loss of normal power and demonstrates unit operability.
5. LED Indicator Light: Indicates normal power on. Normal glow indicates trickle charge; bright glow indicates charging at end of discharge cycle.
6. Wire Guard: Heavy-chrome-plated wire guard protects lamp heads or fixtures.
7. Integral Time-Delay Relay: Holds unit on for fixed interval of 10 minutes when power is restored after an outage.
8. Remote Test: Switch in hand-held remote device aimed in direction of tested unit initiates coded infrared signal. Signal reception by factory-installed infrared receiver in tested unit triggers simulation of loss of its normal power supply, providing visual confirmation of either proper or failed emergency response.
9. Integral Self-Test: Factory-installed electronic device automatically initiates code-required test of unit emergency operation at required intervals. Test failure is annunciated by an integral audible alarm and flashing red LED.
10. Dual Voltage input 120V or 277V AC.

## 2.7 LIGHTING FIXTURE SUPPORT COMPONENTS

- A. Single-Stem Hangers: 1/2-inch steel tubing with swivel ball fittings and ceiling canopy. Finish same as fixture.
- B. Twin-Stem Hangers: Two, 1/2-inch steel tubes with single canopy designed to mount a single fixture. Finish same as fixture.
- C. Wires: ASTM A 641/A 641M, Class 3, soft temper, zinc-coated steel, 12 gage.
- D. Wires for Humid Spaces: ASTM A 580/A 580M, Composition 302 or 304, annealed stainless steel, 12 gage.
- E. Rod Hangers: 3/16-inch minimum diameter, cadmium-plated, threaded steel rod.
- F. Hook Hangers: Integrated assembly matched to fixture and line voltage and equipped with threaded attachment, cord, and locking-type plug.

## **PART 3 - EXECUTION**

### **3.1 INSTALLATION**

- A. Lighting fixtures: Set level, plumb, and square with ceilings and walls. Install lamps in each fixture.
- B. Support for Lighting Fixtures in or on Grid-Type Suspended Ceilings: Use grid as a support element.

For lighting fixtures with a weight of <10 lbs:

- 1. One minimum 12-gauge annealed stainless steel slack wire connected from the fixture housing to the structure.

For lighting fixtures with a weight of 10 - 55 lbs:

- 2. Two minimum 12-gauge annealed stainless steel slack wires connected from the fixture housing to the structure.

For lighting fixtures with a weight of 56> lbs:

- 3. Independently supported to the structure and no slack wires are required.

- C. Suspended Lighting Fixture Support:

- 1. Pendants and Rods: Where longer than 48 inches, brace to limit swinging.
- 2. Stem-Mounted, Single-Unit Fixtures: Suspend with twin-stem hangers.
- 3. Continuous Rows: Use tubing or stem for wiring at one point and tubing or rod for suspension for each unit length of fixture chassis, including one at each end.

- D. Adjust aimable lighting fixtures to provide required light intensities.

### **3.2 FIELD QUALITY CONTROL**

- A. Test for Emergency Lighting: Interrupt power supply to demonstrate proper operation. Verify transfer from normal power to battery and retransfer to normal.
- B. Prepare a written report of tests, inspections, observations, and verifications indicating and interpreting results. If adjustments are made to lighting system, retest to demonstrate compliance with standards.

END OF SECTION 26 51 00

## **SECTION 26 56 00 - EXTERIOR LIGHTING**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. This Section includes the following:
  - 1. Exterior luminaires with lamps and ballasts.

#### **1.3 DEFINITIONS**

- A. CRI: Color-rendering index.

- B. HID: High-intensity discharge.
- C. Luminaire: Complete lighting fixture, including ballast housing if provided.

#### 1.4 SUBMITTALS

- A. Product Data: For each luminaire and support component, arranged in order of lighting unit designation. Include data on features, accessories, finishes, and the following:
  - 1. Physical description of luminaire, including materials, dimensions, effective projected area, and verification of indicated parameters.
  - 2. Details of attaching luminaires and accessories.
  - 3. Details of installation and construction.
  - 4. Luminaire materials.
  - 5. Photometric data based on laboratory tests of each luminaire type, complete with indicated lamps, ballasts, and accessories.
    - a. For indicated luminaires, photometric data shall be certified by a qualified independent testing agency. Photometric data for remaining luminaires shall be certified by manufacturer.
    - b. Photometric data shall be certified by manufacturer's laboratory with a current accreditation under the National Voluntary Laboratory Accreditation Program for Energy Efficient Lighting Products.
  - 6. Photoelectric relays.
  - 7. Ballasts, drivers including energy-efficiency data.
  - 8. Lamps, including life, output, and energy-efficiency data.
  - 9. Means of attaching luminaires to supports, and indication that attachment is suitable for components involved.
- B. Samples for Verification: For products designated for sample submission in Exterior Lighting Device Schedule. Each sample shall include lamps and ballasts.
- C. Lighting illumination calculations for Parking Lot areas. Illumination calculations must be provided for all parking lot fixture layouts, all lighting calculations must be provided electronically. The new LED lighting system design and layout shall be in conformance with the latest IES recommended procedures and ANSI/IES RP-20-14 for Parking Facilities. Lighting calculations shall be developed to identify average illumination levels and lighting power density. Average illumination levels shall not drop below desired target values in accordance with IES recommended practices
- D. Qualification Data: For agencies providing photometric data for lighting fixtures.
- E. Field quality-control test reports.
- F. Operation and Maintenance Data: For luminaires to include in emergency, operation, and maintenance manuals.
- G. Warranty: As specified in this Section.

## 1.5 QUALITY ASSURANCE

- A. Luminaire Photometric Data Testing Laboratory Qualifications. The following are acceptable:
  - 1. Luminaire Photometric Data Testing Laboratory Qualifications: Provided by manufacturers' laboratories that are accredited under the National Volunteer Laboratory Accreditation Program for Energy Efficient Lighting Products.
  - 2. Luminaire Photometric Data Testing Laboratory Qualifications: Provided by an independent agency, with the experience and capability to conduct the testing indicated, that is an NRTL as defined by OSHA in 29 CFR 1910.7.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Comply with IEEE C2, "National Electrical Safety Code."
- D. Comply with NFPA 70.

## 1.6 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace products that fail in materials or workmanship; that corrode; or that fade, stain, perforate, erode, or chalk due to effects of weather or solar radiation within specified warranty period. Manufacturer may exclude lightning damage, hail damage, vandalism, abuse, or unauthorized repairs or alterations from special warranty coverage.
  - 1. Warranty Period for Luminaires: Five years from date of Substantial Completion.

## 1.7 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Lamps: 2 for every 100 of each type and rating installed. Furnish at least one of each type.
  - 2. Glass and Plastic Lenses, Covers, and Other Optical Parts: 3 for every 100 of each type and rating installed. Furnish at least one of each type.
  - 3. Globes and Guards: 1 for every 20 of each type and rating installed. Furnish at least one of each type.

## **PART 2 - PRODUCTS**

### 2.1 REQUIREMENTS FOR INDIVIDUAL EXTERIOR LIGHTING DEVICES

- A. Exterior Lighting Device Type Small Wall Mount:
  - 1. Product must be listed on the DesignLights Consortium Premium qualified products list.

2. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - A. Deco Digital.
  - B. RAB Lighting.
  - C. Sylvania Lighting
  - D. Lithonia
  - E. Maxlite.
  - F. Or District approved equal.
3. Voltage: 120 / 277 -V AC; Contractor to field verify.
4. Finish: Powder Coat Steel or Aluminum
5. Lamps: LED.
6. Wattage: <12 watt
7. Lumens: >1200 lumens
8. Driver: Internal
9. Photoelectric Control: Integrated Photocell
10. Size: < 10 inch height; < 7 inch width
11. Color Temperature (K): 4,000k
12. Optics: Glass Lens, Type 3/4 Distribution

B. Exterior Lighting Device Type Large Wall Mount:

1. Product must be listed on the DesignLights Consortium Premium qualified products list.
2. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - G. Deco Lighting.
  - H. RAB Lighting.
  - I. Lithonia.
  - J. Trace Lighting
  - K. Maxlite.
  - L. Or District approved equal.
3. Voltage: 120 / 277 -V AC; Contractor to field verify.
4. Lamps: LED
5. Photoelectric Control: Photocell
6. CRI: >75
7. Color Temperature (K): 4,000.
8. Lumens: >110 lumens/ watt
9. Lens Type : Glass Only
10. Optics: Type 3/4 Distribution

C. Exterior Lighting Device Type Area Light:

1. Product must be listed on the DesignLights Consortium Premium qualified products list.

2. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - A. Deco Lighting.
  - B. RAB Lighting.
  - C. Philips.
  - D. Lithonia.
  - E. Maxlite.
  - F. Or District approved equal.
3. Voltage: 120 / 277 -V AC; Contractor to field verify.
4. Lamps: LED.
5. Photoelectric Control: Photocell.
6. Lumens: >110 lumens/ watt
7. CRI: >75
8. Color Temperature (K): 4,000.
9. Finish: Bronze powder coated
10. Optics: Type 4 Distribution

D. Exterior Lighting Device Type 6-inch Downlight:

1. Product must be listed on the DesignLights Consortium Premium qualified products list.
2. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - A. Deco Lighting.
  - B. Philips.
  - C. Lithonia.
  - D. Maxlite.
  - E. Or District approved equal.
3. Voltage: 120 - 277V AC. Contractor to field verify.
4. Lamps: LED.
5. Photoelectric Control: Integrally mounted.
6. Color Temperature (K): 4,000.

E. Exterior Lighting Device Type Ceiling Canopy

1. Product must be listed on the DesignLights Consortium Premium qualified products list.
2. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - A. Deco Lighting
  - B. Sylvania Lighting.
  - C. RAB Lighting
  - D. Lithonia Lighting
  - E. Philips Lighting

- F. Or District approved equal.
- 3. Construction: Die cast Aluminum; Powder coating finish
- 4. Color: White or silver
- 5. Maximum depth: 8 inches.
- 6. CRI: >80.
- 7. Voltage: 120 – 277 V AC.
- 8. Wattage: < 35 watts
- 9. Lumens: > 3,500 lumens
- 10. Driver: Internal
- 11. Color Temperature (K): 4,000k
- 12. Optics: Polycarbonate Lens, Type 5 Distribution

F. Exterior Lighting Device Type Area Flood:

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - A. Deco Lighting.
  - B. RAB Lighting.
  - C. Philips.
  - D. Lithonia.
  - E. Maxlite.
  - F. Or District approved equal.
- 2. Voltage: 120 / 277 -V AC; Contractor to field verify.
- 3. Lamps: LED.
- 4. Photoelectric Control: Photocell.
- 5. CRI: >75
- 6. Lumens: > 110 lumens/ watt
- 7. Color Temperature (K): 4,000.
- 8. Finish: Bronze powder coated
- 9. Optics: Type 5 Distribution

## **PART 3 - EXECUTION**

### **3.1 LUMINAIRE INSTALLATION**

- A. Install lamps in each luminaire.
- B. Fasten luminaire to indicate structural supports.
  - 1. Use fastening methods and materials selected to resist seismic forces defined for the application and approved by manufacturer.

- C. Adjust luminaires that require field adjustment or aiming. Include adjustment of photoelectric device to prevent false operation of relay by artificial light sources.

### 3.2 FIELD QUALITY CONTROL

- A. Inspect each installed fixture for damage. Replace damaged fixtures and components.
- B. Illumination Observations: Verify normal operation of lighting units after installing luminaires and energizing circuits with normal power source.
  - 1. Verify operation of photoelectric controls.
- C. Illumination Tests:
  - 1. Measure light intensities at night. Use photometers with calibration referenced to NIST standards. Comply with the following IESNA testing guide(s):
    - A. IESNA LM-5, "Photometric Measurements of Area and Sports Lighting."
    - B. IESNA LM-50, "Photometric Measurements of Roadway Lighting Installations."
    - C. IESNA LM-64, "Photometric Measurements of Parking Areas."
    - D. IESNA LM-72, "Directional Positioning of Photometric Data."
- D. Prepare a written report of tests, inspections, observations, and verifications indicating and interpreting results. If adjustments are made to lighting system, retest to demonstrate compliance with standards.
- E. Fixture Mounting Footprint: If new fixture footprint is smaller than original fixture footprint, Contractor shall repaint or properly furnish base plates or existing colored paint to conceal original fixture footprint accordingly.

### 3.3 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain luminaire lowering devices.

END OF SECTION 26 56 00

## **SECTION 26 09 23 - LIGHTING CONTROL DEVICES**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. This Section includes the following lighting control devices:
  - 1. Time clocks (for exterior lighting fixtures only).
  - 2. Indoor photoelectric switches.
  - 3. Indoor occupancy sensors.
  - 4. Lighting contactors.
  - 5. Emergency shunt relays.

#### **1.3 DEFINITIONS**

- A. LED: Light-emitting diode.
- B. PIR: Passive infrared.

#### **1.4 SUBMITTALS**

- A. Product Data: For each type of product used.

- B. Shop Drawings: Show installation details for occupancy and light-level sensors.
  - 1. Interconnection diagrams showing field-installed wiring.
- C. Field quality-control test reports.
- D. Operation and Maintenance Data: For each type of product to include in emergency, operation, and maintenance manuals.

## 1.5 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

## 1.6 COORDINATION

- B. Coordinate layout and installation of ceiling-mounted devices with other construction that penetrates ceilings or is supported by them, including light fixtures, HVAC equipment, smoke detectors, fire-suppression system, and partition assemblies.

## PART 2 - PRODUCTS

### 2.1 WIRELESS DIMMING CONTROLS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Lutron
  - 2. District approved equal
- B. Description: Control system providing wireless 0-10V dimming to interior fixtures with dimming controlled by a wireless remote.
  - 1. Wireless remote
    - a. Wall-mounted and tethered. User should be able to remove remote from wall-mounting.
    - b. Provide control of lighting within a range of 30 ft
    - c. Communicate using Radio Frequency (RF) at 431 MHz to 437 MHz
    - d. Provide user with on/off control as well as dimming
  - 2. Dimming Module
    - a. Controls up to 60 mA of 0-10V controlled fixtures together
    - b. Switches up to 5 A total
    - c. Receives input from wireless remote and occupancy sensors
    - d. LED indicator showing load status

- e. Power failure memory: If power is interrupted, connected loads will return to the previous level prior to interruption.
- f. 0-10V control miswire protection up to 30V

## 2.2 TIME CLOCKS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- C. Basis-of-Design Product: Subject to compliance with requirements, provide a comparable product by one of the following:
  - 1. Area Lighting Research, Inc.; Tyco Electronics.
  - 2. Grasslin Controls Corporation; a GE Industrial Systems Company.
  - 3. Intermatic, Inc.
  - 4. Leviton Mfg. Company Inc.
  - 5. Lightolier Controls; a Genlyte Company.
  - 6. Lithonia Lighting; Acuity Lighting Group, Inc.
  - 7. Paragon Electric Co.; Invensys Climate Controls.
  - 8. Square D; Schneider Electric.
  - 9. Enlighted.
  - 10. Touch-Plate, Inc.
  - 11. Watt Stopper (The).
  - 12. Lutron;
- D. Electronic Time Clocks: The time switch shall be of the 24-hour electronic type, capable of permitting up to 28 setpoints or events. The time switch shall provide a minimum ON or OFF time of 1 minute. The time switch to be powered by 120/ 277V AC (field verified by Contractor), 60 Hz power supply. The time switch mechanism shall be a snap-in design to provide ease of mechanism removal for mounting the enclosure. The time switch enclosure shall be a Type 3R plastic lockable enclosure, which shall be painted with an electrostatic process to eliminate the potential for corrosion. The time switch shall provide clear terminal identification on a non-curling terminal insulator. Terminal connections shall be made using teeter-type terminal screws to provide secure connections for wire sizes up to #10 AWG.
  - 1. Contact Configuration: SPST, DPST, DPDT.
  - 2. Contact Rating: 20-A ballast load, 120/240-V AC.
  - 3. Astronomic Time: Selected channels.
  - 4. Battery Backup: For schedules and time clock.
- E. BAS Interface: Provide hardware interface to enable the BAS to monitor and control lighting contactors.
  - 1. Monitoring: On-off status.
  - 2. Control: On-off operation.

## 2.3 OUTDOOR PHOTOELECTRIC SWITCHES

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. Area Lighting Research, Inc.; Tyco Electronics.
  2. Grasslin Controls Corporation; a GE Industrial Systems Company.
  3. Intermatic, Inc.
  4. Lithonia Lighting; Acuity Lighting Group, Inc.
  5. Novitas, Inc.
  6. Paragon Electric Co.; Invensys Climate Controls.
  7. Square D; Schneider Electric.
  8. Enlighted.
  9. Touch-Plate, Inc.
  10. Watt Stopper (The).
  11. Lutron.
  12. Or approved equal.
- B. Description: Solid state, with SPST dry contacts rated for 1800-VA tungsten or 1000-VA inductive, to operate connected relay, contactor coils, or microprocessor input; complying with UL 773A.
1. Light-Level Monitoring Range: 1.5 to 10 fc (16.14 to 108 lx), with an adjustment for turn-on and turn-off levels within that range, and a directional lens in front of photocell to prevent fixed light sources from causing turn-off.
  2. Time Delay: 15-second minimum, to prevent false operation.
  3. Surge Protection: Metal-oxide varistor, complying with IEEE C62.41.1, IEEE C62.41.2, and IEEE 62.45 for Category A1 locations.
  4. Mounting: Twist lock complying with IEEE C136.10, with base-and-stem mounting or stem-and-swivel mounting accessories as required to direct sensor to the north sky exposure.
- C. Description: Solid state, with SPST and DPST dry contacts rated for 1800 VA to operate connected load, relay, or contactor coils; complying with UL 773.
1. Light-Level Monitoring Range: 1.5 to 10 fc (16.14 to 108 lx), with an adjustment for turn-on and turn-off levels within that range.
  2. Time Delay: 30-second minimum, to prevent false operation.
  3. Lightning Arrester: Air-gap type.
  4. Mounting: Twist lock complying with IEEE C136.10, with base.

## 2.4 INDOOR PHOTOELECTRIC SWITCHES

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. Lutron
  2. Allen-Bradley/Rockwell Automation.
  3. Area Lighting Research, Inc.; Tyco Electronics.
  4. Eaton Electrical Inc; Cutler-Hammer Products.

5. Grasslin Controls Corporation; a GE Industrial Systems Company.
  6. Intermatic, Inc.
  7. Lithonia Lighting; Acuity Lighting Group, Inc.
  8. MicroLite Lighting Control Systems.
  9. Novitas, Inc.
  10. Paragon Electric Co.; Invensys Climate Controls.
  11. Square D; Schneider Electric.
  12. Enlighted.
  13. Touch-Plate, Inc.
  14. Watt Stopper (The).
  15. Or approved equal.
- B. Ceiling-Mounted Photoelectric Switch: Solid-state, light-level sensor unit, with separate relay unit mounted on luminaire, to detect changes in lighting levels that are perceived by the eye. Cadmium sulfide photoresistors are not acceptable.
1. Sensor Output: Contacts rated to operate the associated relay, complying with UL 773A. Sensor shall be powered from the relay unit.
  2. Relay Unit: Dry contacts rated for 20-A ballast load at 120- and 277-V ac, for 13-A tungsten at 120-V ac, and for 1 hp at 120-V ac. Power supply to sensor shall be 24-V dc, 150-mA, Class 2 power source as defined by NFPA 70.
  3. Light-Level Monitoring Range: 10 to 200 fc (108 to 2152 lx, with an adjustment for turn-on and turn-off levels within that range.
  4. Time Delay: Adjustable from 5 to 300 seconds to prevent cycling, with deadband adjustment.
  5. Indicator: Two LEDs to indicate the beginning of on-off cycles.

## 2.5 INDOOR OCCUPANCY SENSORS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. Lutron.
  2. Hubbell Lighting.
  3. Leviton Mfg. Company Inc.
  4. Lithonia Lighting; Acuity Lighting Group, Inc.
  5. Novitas, Inc.
  6. RAB Lighting, Inc.
  7. Sensor Switch, Inc.
  8. Enlighted.
  9. Watt Stopper (The).
  10. Or approved equal.
- B. General Description: Wall- or ceiling-mounting, solid-state units with a separate relay unit.
1. Operation: Unless otherwise indicated, turn lights on when covered area is occupied and off when unoccupied; with a time delay for turning lights off, adjustable over a minimum range of 1 to 15 minutes.

2. Sensor Output: Contacts rated to operate the connected relay, complying with UL 773A. Sensor shall be powered from the relay unit.
  3. Relay Unit: Dry contacts rated for 20-A ballast load at 120- and 277-V AC, for 13-A tungsten at 120-V AC, and for 1 hp at 120-V AC. Power supply to sensor shall be 24-V DC, 150-mA, Class 2 power source as defined by NFPA 70.
  4. Mounting:
    - A. Sensor: Suitable for mounting in any position on a standard outlet box.
    - B. Relay: Externally mounted through a 1/2-inch knockout in a standard electrical enclosure.
    - C. Time-Delay and Sensitivity Adjustments: Recessed and concealed behind hinged door.
    - D. 20-minute minimum occupancy setting
  5. Indicator: LED, to show when motion is being detected during testing and normal operation of the sensor.
  6. Bypass Switch: Override the on function in case of sensor failure.
  7. Automatic Light-Level Sensor: Adjustable from 2 to 200 fc (21.5 to 2152 lx); keep lighting off when selected lighting level is present.
- C. PIR Type: Ceiling mounting; detect occupancy by sensing a combination of heat and movement in area of coverage.
1. Detector Sensitivity: Detect occurrences of 6-inch- minimum movement of any portion of a human body that presents a target of not less than 36 sq. inches.
  2. Detection Coverage (Room): Detect occupancy anywhere in a circular area of 1000 sq. ft. when mounted on a 96-inch-high ceiling.
  3. Detection Coverage (Corridor): Detect occupancy within 90 feet when mounted on a 10-foot- high ceiling.
  4. 20-minute minimum occupancy setting.
- D. Ultrasonic Type: Ceiling mounting; detect occupancy by sensing a change in pattern of reflected ultrasonic energy in area of coverage.
1. Detector Sensitivity: Detect a person of average size and weight moving not less than 12 inches in either a horizontal or a vertical manner at an approximate speed of 12 inches/s.
  2. Detection Coverage (Small Room): Detect occupancy anywhere within a circular area of 300 sq. ft. when mounted on a 96-inch- high ceiling.
  3. Detection Coverage (Standard Room): Detect occupancy anywhere within a circular area of 600 sq. ft. when mounted on a 96-inch- high ceiling.
  4. Detection Coverage (Large Room): Detect occupancy anywhere within a circular area of 1000 sq. ft. when mounted on a 96-inch- high ceiling.
  5. Detection Coverage (Corridor): Detect occupancy anywhere within 90 feet when mounted on a 10-foot- high ceiling in a corridor not wider than 14 feet.
  6. 20-minute minimum occupancy setting.
- E. Dual-Technology Type: Ceiling mounting; detect occupancy by using a combination of PIR and ultrasonic detection methods in area of coverage. Particular technology or combination of

technologies that controls on-off functions shall be selectable in the field by operating controls on unit.

1. Sensitivity Adjustment: Separate for each sensing technology.
2. Detector Sensitivity: Detect occurrences of 6-inch- minimum movement of any portion of a human body that presents a target of not less than 36 sq. in., and detect a person of average size and weight moving not less than 12 inches in either a horizontal or a vertical manner at an approximate speed of 12 inches/s.
3. Detection Coverage (Standard Room): Detect occupancy anywhere within a circular area of 1000 sq. ft. when mounted on a 96-inch- high ceiling.

## 2.6 OUTDOOR MOTION SENSORS (PIR)

A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

1. Lutron.
2. Bryant Electric; a Hubbell Company.
3. Hubbell Lighting.
4. Lithonia Lighting; Acuity Lighting Group, Inc.
5. Paragon Electric Co.; Invensys Climate Controls.
6. RAB Lighting, Inc.
7. Enlighted.
8. Watt Stopper (The).
9. Or approved equal.

B. Performance Requirements: Suitable for operation in ambient temperatures ranging from minus 40 to plus 167 deg F (minus 40 to plus 75 deg C), IP66 minimum rating for wet and outdoor locations.

1. Operation:

A. Dimming: When motion is detected within the sensor's coverage area, the sensor sends a signal to ramp the load up to the selectable High Mode level unless the ambient light level is higher than the selected set point. When no motion is detected for the duration of the time delay setting, the lights will go to the selectable Low Mode level based on the signal from the sensor. If desired, a cutoff time delay will trigger to eventually turn the lights OFF.

B. Non-dimming: When motion is detected within the sensor's coverage area, the sensor sends a signal to turn the load ON unless the ambient light level is higher than the selected set point. When no motion is detected for the duration of the time delay setting, the lights will go OFF based on the signal from the sensor.

Dusk to dawn control: When photocell on/off is enabled, and the ambient light falls below the photocell setpoint, the sensor ramps the load up to the selectable High Mode level. If no motion is detected for the duration of the time delay setting (factory preset at 5 minutes), the lights will go to the selectable Low Mode level. If the cut off time delay is disabled, the

load will remain on, at High or Low level, based on motion detection, until the ambient light increases above the photocell setpoint

2. Mounting:
    - a. Sensor: Suitable for mounting in any position on a standard outdoor junction box.
    - b. Relay: Internally mounted in a standard weatherproof electrical enclosure.
    - c. Time-Delay and Sensitivity Adjustments: Recessed and concealed behind hinged door.
  3. Bypass Switch: Override the on function in case of sensor failure.
  4. Automatic Light-Level Sensor: Adjustable from 1 to 20 fc (11 to 215 lx); keep lighting off during daylight hours.
- B. Detector Sensitivity: Detect occurrences of 6-inch minimum movement of any portion of a human body that presents a target of not less than 36 sq. inches.
- C. Detection Coverage: Up to 35 feet, with a field of view of 90 degrees.
- D. Lighting Fixture Mounted Sensor: Suitable for switching 300 W of tungsten load at 120- or 277-V ac.
- E. Individually Mounted Sensor: Contacts rated to operate the connected relay, complying with UL 773A. Sensor shall be powered from the relay unit.
1. Relay Unit: Dry contacts rated for 20-A ballast load at 120- and 277-V ac, for 13-A tungsten at 120-V ac, and for 1 hp at 120-V ac. Power supply to sensor shall be 24-V dc, 150-mA, Class 2 power source as defined by NFPA 70.
  2. Indicator: LED, to show when motion is being detected during testing and normal operation of the sensor.

## 2.7 LIGHTING CONTACTORS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. Lutron.
  2. Allen-Bradley/Rockwell Automation.
  3. ASCO Power Technologies, LP; a division of Emerson Electric Co.
  4. Eaton Electrical Inc.; Cutler-Hammer Products.
  5. GE Industrial Systems; Total Lighting Control.
  6. Grasslin Controls Corporation; a GE Industrial Systems Company.
  7. Hubbell Lighting.
  8. Lithonia Lighting; Acuity Lighting Group, Inc.
  9. MicroLite Lighting Control Systems.
  10. Square D; Schneider Electric.
  11. TORK.
  12. Touch-Plate, Inc.
  13. Watt Stopper (The).
  14. Or approved equal.

- B. Description: Electrically operated and electrically held, combination type with fusible switch, complying with NEMA ICS 2 and UL 508.
  - 1. Current Rating for Switching: Listing or rating consistent with type of load served, including tungsten filament, inductive, and high-inrush ballast (ballast with 15 percent or less total harmonic distortion of normal load current).
  - 2. Fault Current Withstand Rating: Equal to or exceeding the available fault current at the point of installation.
  - 3. Enclosure: Comply with NEMA 250.
  - 4. Provide with control and pilot devices as indicated on Drawings, matching the NEMA type specified for the enclosure.

## 2.8 EMERGENCY SHUNT RELAY

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Lutron.
  - 2. Lighting Control and Design, Inc.
  - 3. Watt Stopper (The).
  - 4. Or approved equal.
- B. Description: Normally closed, electrically held relay, arranged for wiring in parallel with manual or automatic switching contacts; complying with UL 924.
  - 1. Coil Rating: 120V.

## 2.9 CONDUCTORS AND CABLES

- A. Power Wiring to Supply Side of Remote-Control Power Sources: Not smaller than No. 12 AWG. Comply with requirements in Division 16 Section "Conductors and Cables."
- B. Classes 2 and 3 Control Cable: Multi-conductor cable with stranded-copper conductors not smaller than No. 18 AWG. Comply with requirements in Division 16 Section "Conductors and Cables."
- C. Class 1 Control Cable: Multi-conductor cable with stranded-copper conductors not smaller than No. 18 AWG. Comply with requirements in Division 16 Section "Conductors and Cables."

## **PART 3 - EXECUTION**

### 3.1 SENSOR INSTALLATION

- A. Install and aim sensors in locations to achieve not less than 90 percent coverage of areas indicated. Do not exceed coverage limits specified in manufacturer's written instructions.

### 3.2 CONTACTOR INSTALLATION

- A. Mount electrically held lighting contactors with elastomeric isolator pads, to eliminate structure-borne vibration, unless contactors are installed in an enclosure with factory-installed vibration isolators.

### 3.3 WIRING INSTALLATION

- A. Wiring Method: Comply with Division 16 Section "Conductors and Cables." Minimum conduit size shall be 1/2 inch.
- B. Wiring within Enclosures: Comply with NECA 1. Separate power-limited and non-power-limited conductors according to conductor manufacturer's written instructions.
- C. Size conductors according to lighting control device manufacturer's written instructions, unless otherwise indicated.
- D. Splices, Taps, and Terminations: Make connections only on numbered terminal strips in junction, pull, and outlet boxes; terminal cabinets; and equipment enclosures.

### 3.4 IDENTIFICATION

- A. Identify components and power and control wiring according to Division 16 Section "Electrical Identification."
  - 1. Identify controlled circuits in lighting contactors.
  - 2. Identify circuits or luminaires controlled by photoelectric and occupancy sensors at each sensor.
- B. Label time switches and contactors with a unique designation.

### 3.5 FIELD QUALITY CONTROL

- A. Perform the following field tests and inspections and prepare test reports:
  - 1. After installing time switches and sensors, and after electrical circuitry has been energized, adjust and test for compliance with requirements.
  - 2. Operational Test: Verify operation of each lighting control device, and adjust time delays.
- B. Lighting control devices that fail tests and inspections are defective work.

### 3.6 ADJUSTING

- A. Occupancy Adjustments: When requested within 12 months of date of Substantial Completion, provide on-site assistance in adjusting sensors to suit occupied conditions. Provide up to two visits to Project during other-than-normal occupancy hours for this purpose.

### 3.7 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain lighting control devices.

END OF SECTION 26 09 23

## **SECTION 26 06 00 - BASIC ELECTRICAL MATERIALS AND METHODS**

### **PART 1 - GENERAL**

#### **1.1. RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 16 Specification Sections, apply to this Section.

#### **1.2. SUMMARY**

- A. This Section includes the following:
  - 1. Building wire and connectors.
  - 2. Supporting devices for electrical components.
  - 3. Electrical identification.
  - 4. Electrical demolition.
  - 5. Cutting and patching for electrical construction.
  - 6. Touchup painting.

#### **1.3. DEFINITIONS**

- A. EMT: Electrical metallic tubing.
- B. FMC: Flexible metal conduit.
- C. IMC: Intermediate metal conduit.
- D. LFMC: Liquidtight flexible metal conduit.
- E. RNC: Rigid nonmetallic conduit.

#### **1.4. SUBMITTALS**

- A. Shop Drawings: Dimensioned plans and sections or elevation layouts
- B. Field Test Reports: Indicate and interpret test results for compliance with performance requirements.

#### **1.5. QUALITY ASSURANCE**

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. Comply with NFPA 70.

## 1.6. COORDINATION

- A. Coordinate chases, slots, inserts, sleeves, and openings with general construction work and arrange in building structure during progress of construction to facilitate the electrical installations that follow.
  - 1. Set inserts and sleeves in poured-in-place concrete, masonry work, and other structural components as they are constructed.
- B. Sequence, coordinate, and integrate installing electrical materials and equipment for efficient flow of the Work. Coordinate installing large equipment requiring positioning before closing in the building.
- C. Coordinate electrical service connections to components furnished by utility companies.
  - 1. Coordinate installation and connection of exterior underground and overhead utilities and services, including provision for electricity-metering components.
  - 2. Comply with requirements of authorities having jurisdiction and of utility company providing electrical power and other services.
- D. Coordinate location of access panels and doors for electrical items that are concealed by finished surfaces.
- E. Where electrical identification devices are applied to field-finished surfaces, coordinate installation of identification devices with completion of finished surface.
- F. Where electrical identification markings and devices will be concealed by acoustical ceilings and similar finishes, coordinate installation of these items before ceiling installation.

## PART 2 - PRODUCTS

### 2.1. CONDUCTORS

- A. Conductors, No. 10 AWG and Smaller: Solid or stranded copper.
- B. Conductors, Larger Than No. 10 AWG: Stranded copper.
- C. Insulation: Thermoplastic, rated at 75 deg. C minimum.
- D. Wire Connectors and Splices: Units of size, ampacity rating, material, type, and class suitable for service indicated.

### 2.2. SUPPORTING DEVICES

- A. Material: Cold-formed steel, with corrosion-resistant coating acceptable to authorities having jurisdiction.
- B. Metal Items for Use Outdoors or in Damp Locations: Hot-dip galvanized steel.

- C. Slotted-Steel Channel Supports: Flange edges turned toward web, and 9/16-inch- diameter slotted holes at a maximum of 2 inches o.c., in webs.
- D. Nonmetallic Channel and Angle Systems: Structural-grade, factory-formed, glass-fiber-resin channels and angles with 9/16-inch- diameter holes at a maximum of 8 inches o.c., in at least one surface.
  - 1. Fittings and Accessories: Products of the same manufacturer as channels and angles.
  - 2. Fittings and Accessory Materials: Same as channels and angles, except metal items may be stainless steel.
- E. Raceway and Cable Supports: Manufactured clevis hangers, riser clamps, straps, threaded C-clamps with retainers, ceiling trapeze hangers, wall brackets, and spring-steel clamps or click-type hangers.
- F. Pipe Sleeves: ASTM A 53, Type E, Grade A, Schedule 40, galvanized steel, plain ends.
- G. Cable Supports for Vertical Conduit: Factory-fabricated assembly consisting of threaded body and insulating wedging plug for nonarmored electrical cables in riser conduits. Plugs have number and size of conductor gripping holes as required to suit individual risers. Body constructed of malleable-iron casting with hot-dip galvanized finish.
- H. Expansion Anchors: Carbon-steel wedge or sleeve type.
- I. Toggle Bolts: All-steel springhead type.
- J. Powder-Driven Threaded Studs: Heat-treated steel.

### 2.3. ELECTRICAL IDENTIFICATION

- A. Identification Devices: A single type of identification product for each application category. Use colors prescribed by ANSI A13.1, NFPA 70, and these Specifications.
- B. Raceway and Cable Labels: Comply with ANSI A13.1, Table 3, for minimum size of letters for legend and minimum length of color field for each raceway and cable size.
  - 1. Type: Pre-tensioned, wraparound plastic sleeves. Flexible, preprinted, color-coded, acrylic band sized to suit the diameter of the item it identifies.
  - 2. Type: Preprinted, flexible, self-adhesive, vinyl. Legend is over-laminated with a clear, weather- and chemical-resistant coating.
  - 3. Color: Black letters on orange background.
  - 4. Legend: Indicates voltage.
- C. Colored Adhesive Marking Tape for Raceways, Wires, and Cables: Self-adhesive vinyl tape, not less than 1-inch-wide by 3 mils thick.
- D. Underground Warning Tape: Permanent, bright-colored, continuous-printed, vinyl tape with the following features:
  - 1. Not less than 6 inches wide by 4 mils thick.

2. Compounded for permanent direct-burial service.
  3. Embedded continuous metallic strip or core.
  4. Printed legend that indicates type of underground line.
- E. Tape Markers for Wire: Vinyl or vinyl-cloth, self-adhesive, wraparound type with pre-printed numbers and letters.

#### 2.4. TOUCHUP PAINT

- A. For Equipment: Equipment manufacturer's paint selected to match installed equipment finish.
- B. Galvanized Surfaces: Zinc-rich paint recommended by item manufacturer.

### **PART 3 - EXECUTION**

#### 3.1. ELECTRICAL EQUIPMENT INSTALLATION

- A. Headroom Maintenance: If mounting heights or other location criteria are not indicated, arrange and install components and equipment to provide the maximum possible headroom.
- B. Materials and Components: Install level, plumb, and parallel and perpendicular to other building systems and components, unless otherwise indicated.
- C. Equipment: Install to facilitate service, maintenance, and repair or replacement of components. Connect for ease of disconnecting, with minimum interference with other installations.
- D. Right of Way: Give to raceways and piping systems installed at a required slope.

#### 3.2. WIRING METHODS FOR POWER, LIGHTING, AND CONTROL CIRCUITS

- A. Feeders: Type THHN/THWN insulated conductors in raceway.
- B. Underground Feeders and Branch Circuits: Type THWN or single-wire, Type UF insulated conductors in raceway.
- C. Branch Circuits: Type THHN/THWN insulated conductors in raceway.
- D. Remote-Control Signaling and Power-Limited Circuits: Type THHN/THWN insulated conductors in raceway for Classes 1, 2, and 3, unless otherwise indicated.

#### 3.3. WIRING INSTALLATION

- A. Install splices and taps that are compatible with conductor material and that possess equivalent or better mechanical strength and insulation ratings than unspliced conductors.

- B. Install wiring at outlets with at least 12 inches of slack conductor at each outlet.
- C. Connect outlet and component connections to wiring systems and to ground. Tighten electrical connectors and terminals, according to manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A.

#### 3.4. ELECTRICAL SUPPORTING DEVICE APPLICATION

- A. Damp Locations and Outdoors: Hot-dip galvanized materials or nonmetallic, U-channel system components.
- B. Dry Locations: Steel materials.
- C. Support Clamps for PVC Raceways: Click-type clamp system.
- D. Selection of Supports: Comply with manufacturer's written instructions.
- E. Strength of Supports: Adequate to carry present and future loads, times a safety factor of at least four; minimum of 200-lb (90-kg) design load.

#### 3.5. SUPPORT INSTALLATION

- A. Install support devices to securely and permanently fasten and support electrical components.
- B. Install individual and multiple raceway hangers and riser clamps to support raceways. Provide U-bolts, clamps, attachments, and other hardware necessary for hanger assemblies and for securing hanger rods and conduits.
- C. Support parallel runs of horizontal raceways together on trapeze- or bracket-type hangers.
- D. Size supports for multiple raceway installations so capacity can be increased by a 25 percent minimum in the future.
- E. Support individual horizontal raceways with separate, malleable-iron pipe hangers or clamps.
- F. Install 1/4-inch- diameter or larger threaded steel hanger rods, unless otherwise indicated.
- G. Spring-steel fasteners specifically designed for supporting single conduits or tubing may be used instead of malleable-iron hangers for 1-1/2-inch and smaller raceways serving lighting and receptacle branch circuits above suspended ceilings and for fastening raceways to slotted channel and angle supports.
- H. Arrange supports in vertical runs so the weight of raceways and enclosed conductors is carried entirely by raceway supports, with no weight load on raceway terminals.
- I. Simultaneously install vertical conductor supports with conductors.

- J. Separately support cast boxes that are threaded to raceways and used for fixture support. Support sheet-metal boxes directly from the building structure or by bar hangers. If bar hangers are used, attach bar to raceways on opposite sides of the box and support the raceway with an approved fastener not more than 24 inches from the box.
- K. Install metal channel racks for mounting cabinets, panelboards, disconnect switches, control enclosures, pull and junction boxes, transformers, and other devices unless components are mounted directly to structural elements of adequate strength.
- L. Install sleeves for cable and raceway penetrations of concrete slabs and walls unless core-drilled holes are used. Install sleeves for cable and raceway penetrations of masonry and fire-rated gypsum walls and of all other fire-rated floor and wall assemblies. Install sleeves during erection of concrete and masonry walls.
- M. Securely fasten electrical items and their supports to the building structure, unless otherwise indicated. Perform fastening according to the following unless other fastening methods are indicated:
  - 1. Wood: Fasten with wood screws or screw-type nails.
  - 2. Masonry: Toggle bolts on hollow masonry units and expansion bolts on solid masonry units.
  - 3. New Concrete: Concrete inserts with machine screws and bolts.
  - 4. Existing Concrete: Expansion bolts.
  - 5. Instead of expansion bolts, threaded studs driven by a powder charge and provided with lock washers may be used in existing concrete.
  - 6. Steel: Welded threaded studs or spring-tension clamps on steel.
    - a. Field Welding: Comply with AWS D1.1.
  - 7. Welding to steel structure may be used only for threaded studs, not for conduits, pipe straps, or other items.
  - 8. Light Steel: Sheet-metal screws.
  - 9. Fasteners: Select so the load applied to each fastener does not exceed 25 percent of its proof-test load.

### 3.6. IDENTIFICATION MATERIALS AND DEVICES

- A. Install at locations for most convenient viewing without interference with operation and maintenance of equipment.
- B. Coordinate names, abbreviations, colors, and other designations used for electrical identification with corresponding designations indicated in the Contract Documents or required by codes and standards. Use consistent designations throughout Project.
- C. Self-Adhesive Identification Products: Clean surfaces before applying.
- D. Identify raceways and cables with color banding as follows:

1. Bands: Pretensioned, snap-around, colored plastic sleeves or colored adhesive marking tape. Make each color band 2 inches wide, completely encircling conduit, and place adjacent bands of two-color markings in contact, side by side.
  2. Band Locations: At changes in direction, at penetrations of walls and floors, at 50-foot maximum intervals in straight runs, and at 25-foot maximum intervals in congested areas.
  3. Colors: As follows:
    - a. Fire Alarm System: Red.
    - b. Security System: Blue and yellow.
    - c. Telecommunication System: Green and yellow.
- E. Tag and label circuits designated to be extended in the future. Identify source and circuit numbers in each cabinet, pull and junction box, and outlet box. Color-coding may be used for voltage and phase identification.
- F. Install continuous underground plastic markers during trench backfilling, for exterior underground power, control, signal, and communication lines located directly above power and communication lines. Locate 6 to 8 inches below finished grade. If width of multiple lines installed in a common trench or concrete envelope does not exceed 16 inches, overall, use a single line marker.
- G. Color-code 208/120-V system secondary service, feeder, and branch-circuit conductors throughout the secondary electrical system as follows:
  1. Phase A: Black.
  2. Phase B: Red.
  3. Phase C: Blue.
- H. Color-code 480/277-V system secondary service, feeder, and branch-circuit conductors throughout the secondary electrical system as follows:
  1. Phase A: Yellow.
  2. Phase B: Brown.
  3. Phase C: Orange.
- I. Install warning, caution, and instruction signs where required to comply with 29 CFR, Chapter XVII, Part 1910.145, and where needed to ensure safe operation and maintenance of electrical systems and of items to which they connect. Install engraved plastic-laminated instruction signs with approved legend where instructions are needed for system or equipment operation. Install metal-backed butyrate signs for outdoor items.
- J. Install engraved-laminated emergency-operating signs with white letters on red background with minimum 3/8-inch- high lettering for emergency instructions on power transfer, load shedding, and other emergency operations.

### 3.7. DEMOLITION

- A. Protect existing electrical equipment and installations indicated to remain. If damaged or disturbed in the course of the Work, remove damaged portions and install new products of equal capacity, quality, and functionality.
- B. Accessible Work: Remove exposed electrical equipment and installations, indicated to be demolished, in their entirety.
- C. Abandoned Work: Cut and remove buried raceway and wiring, indicated to be abandoned in place, 2 inches below the surface of adjacent construction. Cap raceways and patch surface to match existing finish.
- D. Remove demolished material from Project site.
- E. Remove, store, clean, reinstall, reconnect, and make operational components indicated for relocation.

### 3.8. CUTTING AND PATCHING

- A. Cut, channel, chase, and drill floors, walls, partitions, ceilings, and other surfaces required to permit electrical installations. Perform cutting by skilled mechanics of trades involved.
- B. Repair and refinish disturbed finish materials and other surfaces to match adjacent undisturbed surfaces. Install new fireproofing where existing firestopping has been disturbed. Repair and refinish materials and other surfaces by skilled mechanics of trades involved.

### 3.9. FIELD QUALITY CONTROL

- A. Inspect installed components for damage and faulty work, including the following:
  - 1. Raceways.
  - 2. Building wire and connectors.
  - 3. Supporting devices for electrical components.
  - 4. Electrical identification.
  - 5. Electricity-metering components.
  - 6. Concrete bases.
  - 7. Electrical demolition.
  - 8. Cutting and patching for electrical construction.
  - 9. Touchup painting.

### 3.10. REFINISHING AND TOUCHUP PAINTING

- A. Refinish and touch up paint.
  - 1. Clean damaged and disturbed areas and apply primer, intermediate, and finish coats to suit the degree of damage at each location.

2. Follow paint manufacturer's written instructions for surface preparation and for timing and application of successive coats.
3. Repair damage to galvanized finishes with zinc-rich paint recommended by manufacturer.
4. Repair damage to PVC or paint finishes with matching touchup coating recommended by manufacturer.

### 3.11. CLEANING AND PROTECTION

- A. On completion of installation, including outlets, fittings, and devices, inspect exposed finish. Remove burrs, dirt, paint spots, and construction debris.
- B. Protect equipment and installations and maintain conditions to ensure that coatings, finishes, and cabinets are without damage or deterioration at time of Substantial Completion.

END OF SECTION 26 06 00

## **SECTION 26 05 13 - CONDUCTORS AND CABLES**

### **PART 4 - GENERAL**

#### **4.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

#### **4.2 SUMMARY**

- A. This Section includes the following:
  - 1. Building wires and cables rated 600 V and less.
  - 2. Connectors, splices, and terminations rated 600 V and less.
  - 3. Sleeves and sleeve seals for cables.

#### **4.3 DEFINITIONS**

- A. EPDM: Ethylene-propylene-diene terpolymer rubber.
- B. NBR: Acrylonitrile-butadiene rubber.

#### **4.4 SUBMITTALS**

- A. Product Data: For each type of product indicated.
- B. Qualification Data: For testing agency.
- C. Field quality-control test reports.

#### **4.5 QUALITY ASSURANCE**

- A. Testing Agency Qualifications: An independent agency, with the experience and capability to conduct the testing indicated, that is a member company of the International Electrical Testing Association or is a nationally recognized testing laboratory (NRTL) as defined by OSHA in 29 CFR 1910.7, and that is acceptable to authorities having jurisdiction.
  - 1. Testing Agency's Field Supervisor: Person currently certified by the International Electrical Testing Association or the National Institute for Certification in Engineering Technologies to supervise on-site testing specified in Part 3.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

- C. Comply with NFPA 70.

#### 4.6 COORDINATION

- A. Set sleeves in cast-in-place concrete, masonry walls, and other structural components as they are constructed.

### **PART 5 - PRODUCTS**

#### 5.1 CONDUCTORS AND CABLES

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Alcan Products Corporation; Alcan Cable Division.
  - 2. American Insulated Wire Corp.; a Leviton Company.
  - 3. General Cable Corporation.
  - 4. Senator Wire & Cable Company.
  - 5. Southwire Company.
  - 6. Or by district approved equal.
- B. Copper Conductors: Comply with NEMA WC 70.
- C. Conductor Insulation: Comply with NEMA WC 70 for Types THW and THHN-THWN.

#### 5.2 CONNECTORS AND SPLICES

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. AFC Cable Systems, Inc.
  - 2. Hubbell Power Systems, Inc.
  - 3. O-Z/Gedney; EGS Electrical Group LLC.
  - 4. 3M; Electrical Products Division.
  - 5. Tyco Electronics Corp.
  - 6. Or approved equal.
- B. Description: Factory-fabricated connectors and splices of size, ampacity rating, material, type, and class for application and service indicated.

### **PART 6 - EXECUTION**

#### 6.1 CONDUCTOR MATERIAL APPLICATIONS

- A. Feeders: Copper. Solid for No. 10 AWG and smaller; stranded for No. 8 AWG and larger.

- B. Branch Circuits: Copper. Solid for No. 10 AWG and smaller; stranded for No. 8 AWG and larger.

## 6.2 CONDUCTOR INSULATION AND MULTICONDUCTOR CABLE APPLICATIONS AND WIRING METHODS

- A. Exposed Branch Circuits, Including in Crawlspace: Type THHN-THWN, single conductors in raceway.
- B. Branch Circuits Concealed in Ceilings, Walls, and Partitions: Type THHN-THWN, single conductors in raceway.
- C. Branch Circuits Concealed in Concrete, below Slabs-on-Grade, and Underground: Type THHN-THWN, single conductors in raceway.
- D. Branch Circuits Installed below raised flooring: Type THHN-THWN, single conductors in raceway.
- E. Branch Circuits in Cable Tray: Type THHN-THWN, single conductors in raceway.
- F. Class 1 Control Circuits: Type THHN-THWN, in raceway.
- G. Class 2 Control Circuits: Type THHN-THWN, in raceway.

## 6.3 INSTALLATION OF CONDUCTORS AND CABLES

- A. Conceal cables in finished walls, ceilings, and floors, unless otherwise indicated.
- B. Use manufacturer-approved pulling compound or lubricant where necessary; compound used must not deteriorate conductor or insulation. Do not exceed manufacturer's recommended maximum pulling tensions and sidewall pressure values.
- C. Use pulling means, including fish tape, cable, rope, and basket-weave wire/cable grips, that will not damage cables or raceway.
- D. Install exposed cables parallel and perpendicular to surfaces of exposed structural members, and follow surface contours where possible.
- E. Support cables according to Division 16 Section "Electrical Supports and Seismic Restraints."
- F. Identify and color-code conductors and cables according to Division 16 Section "Electrical Identification."

## 6.4 CONNECTIONS

- A. Tighten electrical connectors and terminals according to manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A and UL 486B.

- B. Make splices and taps that are compatible with conductor material and that possess equivalent or better mechanical strength and insulation ratings than unspliced conductors.
  - 1. Use oxide inhibitor in each splice and tap conductor for aluminum conductors.

#### 6.5 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections and prepare test reports.
- B. Perform tests and inspections and prepare test reports.
- C. Tests and Inspections:
  - 1. After installing conductors and cables and before electrical circuitry has been energized, test all light fixtures for compliance with requirements.
  - 2. Perform each visual and mechanical inspection and electrical test stated in NETA Acceptance Testing Specification. Certify compliance with test parameters.
- D. Test Reports: Prepare a written report to record the following:
  - 1. Test procedures used.
  - 2. Test results that comply with requirements.
  - 3. Test results that do not comply with requirements and corrective action taken to achieve compliance with requirements.
- E. Remove and replace malfunctioning units and retest as specified above.

END OF SECTION 26 05 13