



Delivering more than just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 8/31/2016

WO#: 1608834
 CLIENT: McCowan Clinical Laboratory, Inc.
 Project: Brookings School District 17-C
 PWS Number:
 Sample Source:

Received Date: 8/17/2016 12:10:00 PM
 Sampler Name Brad Peters
 Matrix: Drinking Water
 Sample Type:

Lab ID: 1608834-001 Client Sample ID K-School Room 12 Collection Date: 8/16/2016 8:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00565	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608834-002 Client Sample ID K-School Cafeteria Collection Date: 8/16/2016 8:42:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00759	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608834-003 Client Sample ID K-School Drinking Fountain Collection Date: 8/16/2016 8:38:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608834-004 Client Sample ID K-School Rm 20 Collection Date: 8/16/2016 8:35:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00938	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608834-005 Client Sample ID K-School Office Collection Date: 8/16/2016 8:20:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608834-006 Client Sample ID K-School Life Skills Collection Date: 8/16/2016 8:24:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608834-007 Client Sample ID K-School Rm 4 Collection Date: 8/16/2016 8:32:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0103	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608834-008 Client Sample ID K-School Staff Room Collection Date: 8/16/2016 8:26:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Qualifiers: * Value exceeds Maximum Contaminant Level (MCL) A Accredited by ORELAP
 C Value is below Minimum Compound Limit. E Value above quantitation range
 H Holding times for preparation or analysis exceeded LOD Limit of Detection
 MCL Maximum Contaminant Level NAR See note in Case Narrative
 ND Not Detected at the Reporting Limit PL Permit Limit



Delivering more than just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Analytical Report

Date Reported 8/31/2016

WO#: 1608833
CLIENT: McCowan Clinical Laboratory, Inc.
Project: Brookings School District 17-C
PWS Number:
Sample Source:

Received Date: 8/17/2016 12:10:00 PM
Sampler Name Brad Peters
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID				Collection Date:			
Analyses	Method	Result	MCL	RL Qual	Units	Date Analyzed	Analys	
Lead	SM 3113 B	0.00408	0.0200	0.00200	mg/L	8/30/2016 7:18:00 AM	PG	
Lead	SM 3113 B	0.00487	0.0200	0.00200	mg/L	8/30/2016 7:18:00 AM	PG	
Lead	SM 3113 B	0.0229	0.0200	0.00400 *	mg/L	8/30/2016 7:18:00 AM	PG	
Lead	SM 3113 B	ND	0.0200	0.00200	mg/L	8/30/2016 7:18:00 AM	PG	
Lead	SM 3113 B	ND	0.0150	0.00200	mg/L	8/30/2016 7:18:00 AM	PG	

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 8/31/2016

WO#: 1608837
CLIENT: McCowan Clinical Laboratory, Inc.
Project: Brookings School District 17-C
PWS Number:
Sample Source:

Received Date: 8/17/2016 12:10:00 PM
Sampler Name: Brad Peters
Matrix: Drinking Water
Sample Type:

Lab ID: 1608837-001 **Client Sample ID** Azalea Office **Collection Date:** 8/16/2016 7:38:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608837-002 **Client Sample ID** Azalea Kitchen **Collection Date:** 8/16/2016 7:48:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00417	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608837-003 **Client Sample ID** Azalea Rm 9 **Collection Date:** 8/16/2016 7:30:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0172	0.0150	0.00400	*	mg/L	8/31/2016 7:13:00 AM	PG

Lab ID: 1608837-004 **Client Sample ID** Azalea Staff L **Collection Date:** 8/16/2016 7:40:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00426	0.0150	0.00200		mg/L	8/31/2016 7:13:00 AM	PG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 8/31/2016

WO#: 1608878
 CLIENT: McCowan Clinical Laboratory, Inc.
 Project: Brookings School District 17-C
 PWS Number:
 Sample Source:

Received Date: 8/17/2016 12:10:00 PM
 Sampler Name Brad Peters
 Matrix: Drinking Water
 Sample Type:

Lab ID: 1608878-001 Client Sample ID High School Drink 3 Fountain Collection Date: 8/16/2016 8:10:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	8/30/2016 7:18:00 AM	PG

Lab ID: 1608878-002 Client Sample ID High School Cafeteria Collection Date: 8/16/2016 8:12:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0123	0.0150	0.00200		mg/L	8/30/2016 7:18:00 AM	PG

Lab ID: 1608878-003 Client Sample ID High School Boy Bathroom Collection Date: 8/16/2016 8:05:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0325	0.0200	0.00400	*	mg/L	8/30/2016 7:18:00 AM	PG

Qualifiers: * Value exceeds Maximum Contaminant Level (MCL) A Accredited by ORELAP
 C Value is below Minimum Compound Limit. E Value above quantitation range
 H Holding times for preparation or analysis exceeded LOD Limit of Detection
 MCL Maximum Contaminant Level NAR See note in Case Narrative
 ND Not Detected at the Reporting Limit PL Permit Limit



ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 7/21/2016

WO#: 1607656
CLIENT: McCowan Clinical Laboratory, Inc.
Project: Kalmiopsis Brookings School District
PWS Number:
Sample Source:

Received Date: 7/14/2016 12:05:00 PM
Sampler Name: New Hope
Matrix: Drinking Water
Sample Type:

Lab ID: 1607656-001 **Client Sample ID** Drinking Fountain **Collection Date:** 7/13/2016 8:44:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607656-002 **Client Sample ID** Drinking Fountain **Collection Date:** 7/13/2016 8:39:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607656-003 **Client Sample ID** Drinking Fountain **Collection Date:** 7/13/2016 8:41:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit



Delivering more than just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 7/21/2016

WO#: 1607655
CLIENT: McCowan Clinical Laboratory, Inc.
Project: Azalea Brookings School District
PWS Number:
Sample Source:

Received Date: 7/14/2016 12:05:00 PM
Sampler Name: New Hope
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	Drinking Fountain			Collection Date:			
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00432	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	Drinking Fountain			Collection Date:			
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00369	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID:	Client Sample ID	Drinking Fountain			Collection Date:			
Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00270	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 7/21/2016

WO#: 1607654
CLIENT: McCowan Clinical Laboratory, Inc.
Project: BHHS Brookings School District
PWS Number:
Sample Source:

Received Date: 7/14/2016 12:05:00 PM
Sampler Name: New Hope
Matrix: Drinking Water
Sample Type:

Lab ID: 1607654-001 **Client Sample ID** Drinking Fountain **Collection Date:** 7/13/2016 8:00:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	ND	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607654-002 **Client Sample ID** Bath Lav **Collection Date:** 7/13/2016 8:09:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00289	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607654-003 **Client Sample ID** Drinking Fountain **Collection Date:** 7/13/2016 8:11:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00663	0.0200	0.00200		mg/L	7/19/2016 7:44:00 AM	KG

Lab ID: 1607654-004 **Client Sample ID** Bath Lav **Collection Date:** 7/13/2016 8:16:00 AM

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0242	0.0200	0.00400	*	mg/L	7/19/2016 7:44:00 AM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit

Created by EN 8/15/16

OAR 581-022-2223

Healthy and Safe Schools Plan

- (1) Each school district and public charter school must develop a Healthy and Safe Schools Plan for all buildings owned or leased by the school district or public charter school where students and staff are present on a regular basis.
- (2) On or before October 1, 2016, school districts and public charter schools must report to the local school board or charter board on all elements of the Healthy and Safe Schools Plan as described in subsection (5) of this rule.
- (3) School districts and public charter schools must submit a preliminary draft of the Healthy and Safe Schools Plan to the Department of Education on or before October 1, 2016. School districts and public charter schools must submit the final draft of the Healthy and Safe Schools Plan to the Department of Education on or before January 1, 2017. Thereafter, school districts and public charter schools must annually submit an updated Healthy and Safe Schools Plan if new buildings are acquired, constructed, or leased or if the plan is modified by the school district or public charter school.
- (4) The Department of Education shall develop a model Healthy and Safe Schools Plan. The Department shall seek the input of the Oregon Health Authority Public Health Division, the Oregon Department of Environmental Quality and other stakeholders in developing the model plan. The model plan shall be made available on or before September 15, 2016.
- (5) At a minimum, the Healthy and Safe Schools Plan must include:
 - (a) The position within the school district's or public charter school's administration responsible for maintaining and implementing the Healthy and Safe Schools Plan;
 - (b) A list of all facilities that are included in the school district's or public charter school's Plan;
 - (c) A plan to test for elevated levels of radon as required under ORS 332.167;
 - (d) A plan to test for and reduce exposure to lead in water used for drinking or food preparation. An Oregon Health Authority accredited lab must be used for all testing.
 - (e) A plan to reduce exposure to lead paint that includes the following compliance with the United States Environmental Protection Agency's Renovation, Repair and Painting Program Rule.
 - (f) A plan to implement integrated pest management practices as required under ORS 634.700 through 634.750; and

- (g) A plan to communicate results for all tests required under the Healthy and Safe Schools Plan that includes:
 - (A) The school district or public charter school must make all test results available to the public within five business days of receiving the results;
 - (B) The school district or public charter school must make the results available to the public by posting the results on the school district or public charter school website, sending notice of the results over the email system, and making the results available in hardcopy at the main administration office; and
 - (C) The school district or public charter school must provide detailed information explaining the test results.

- (6) School districts and public charter schools must annually provide a statement regarding the Healthy and Safe Schools Plan.
 - (a) The annual statement must be made to the following:
 - (A) The school district or charter school board;
 - (B) All building occupants or for occupants who are under the age of 18, their parents or legal guardians; and
 - (C) The community by posting information on the school district or public charter school website and making the information available at the main administrating building.

 - (b) The annual statement must include the following information:
 - (A) The position within the school district's or public charter school's administration responsible for maintaining and implementing the Healthy and Safe Schools Plan;
 - (B) How to obtain a copy of the Safe and Healthy Schools Plan;
 - (C) A certification that the Healthy and Safe School Plan is up to date and that all required testing has been completed;
 - (D) How to access any results for tests conducted pursuant to the Plan; and
 - (E) A high level summary of major mitigation efforts in the last year as a result of the Healthy and Safe Schools Plan.

- (7) The reports due under subsection (5) of this rule are in addition to any reporting required by any other regulatory authority under state or federal law.

Stat. Auth.: ORS 326.051

Stat. Implemented: ORS 326.051