

Procedure and Timeline Drinking Water Testing

Greene County Schools will adhere to Board Policy 3.212 by observing the following procedures.

1. The maintenance department will conduct drinking water test for lead every two years at all locations built before January 1, 1998.
2. All water fountains will be tested.
3. Food prep sink in each school kitchen will be tested.
4. Samples will be directed to an independent certified lab for testing.
5. The certified labs will provide test results within fourteen days of the samples taken.
6. Response to the testing results will follow the recommendations set by Board Policy 3.212.