

E-RATE Year 22 (2019-2020)  
REQUEST FOR PROPOSAL

**470 # 190002288**

Firebaugh Last Deltas Unified School District  
BID/RFP: #22-T101: FLDUSD Structured Cabling, Erate Public Works, Project

Questions & Answers – Addendum 1

EVENT	DATE
1. Posting of Addendum #1	11/8/2018
2. Revised Due Date for Request for Proposals	12/6/2018 @ 1:00pm, PST

**Question:** When will this project start?

**Answer:** Please refer to the RFP page 63, Article 2 – Contract Term.

**Question:** Are you looking to do this project during school hours? If so, when?

**Answer:** Please reference the RFP on page 43 under “Work Hours”.

**Question:** For the Scope of Work, it states that the bidder will remove existing cabling.

**Answer:** RFP clarification for page 13 Existing Cabling should read.

**Existing Cabling:**

- Existing CAT 6 Leviton cabling and drops shall be left intact
- **Existing Fiber runs shall be left intact**

**Question:** On the Scope of Work, it states that inner duct will be used where there is no duct work. During the walkthrough, we found two locations that don't have duct work.

**Answer:** Please reference the RFP pages 13 (Pathways) and page 14 (Raceways) for Project Specifications.

**RFP Clarification:** RFP page 13, Project Specifications, Fiber Cabling bullet #4 should read:

- Tight Buffer **or** Loose tube (no gel)

**All other terms and conditions remain the same.**

**End of Addendum #1.**