

**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

September 07, 2018

Mr. George Lambesis

KOMENSKY ELEMENTARY SCHOOL

2515 Cuyler Ave

Berwyn, IL 60402

Project ID: Komensky Elementary School

First Environmental File ID: 18-5152

Date Received: September 05, 2018

Dear Mr. George Lambesis:


The above referenced project was analyzed as directed on the enclosed chain of custody record.

All Quality Control criteria as outlined in the methods and current IL ELAP/NELAP have been met unless otherwise noted. QA/QC documentation and raw data will remain on file for future reference. Our accreditation number is 100292 and our current certificate is number 004324: effective 02/27/2018 through 02/28/2019.

I thank you for the opportunity to be of service to you and look forward to working with you again in the future. Should you have any questions regarding any of the enclosed analytical data or need additional information, please contact me at (630) 778-1200.

Sincerely,

Neal Cleghorn
Project Manager



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Case Narrative

KOMENSKY ELEMENTARY SCHOOL

Lab File ID: **18-5152**


Project ID: **Komensky Elementary School**

Date Received: **September 05, 2018**

All quality control criteria, as outlined in the methods, have been met except as noted below or on the following analytical report.

The results in this report apply to the samples in the following table:

Laboratory Sample ID	Sample Identifier	Location Description	Type	Date/Time Collected
18-5152-001	room 108	west wall	FDRW	09/05/18 6:57
18-5152-002	room 108	west wall	FLSH	09/05/18 6:58
18-5152-003	1st fl hall	by 2n door	FDRW	09/05/18 6:59
18-5152-004	1st fl hall	by 2n door	FLSH	09/05/18 7:00
18-5152-005	room 111	south wall	FDRW	09/05/18 7:02
18-5152-006	room 111	south wall	FLSH	09/05/18 7:03
18-5152-007	gym	north wall	FDRW	09/05/18 7:04
18-5152-008	gym	north wall	FLSH	09/05/18 7:05
18-5152-009	1st fl hall	by 5n door	FDRW	09/05/18 7:05
18-5152-010	1st fl hall	by 5n door	FLSH	09/05/18 7:06
18-5152-011	room 125	south wall	FDRW	09/05/18 7:08
18-5152-012	room 125	south wall	FLSH	09/05/18 7:10
18-5152-013	room 129	north wall	FDRW	09/05/18 7:12
18-5152-014	room 129	north wall	FLSH	09/05/18 7:13
18-5152-015	1st fl hall	by rm 137	FDRW	09/05/18 7:15
18-5152-016	1st fl hall	by rm 137	FLSH	09/05/18 7:16
18-5152-017	2nd fl east hall	by rm 235	FDRW	09/05/18 7:17
18-5152-018	2nd fl east hall	by rm 235	FLSH	09/05/18 7:18
18-5152-019	room 223	north wall	FDRW	09/05/18 7:19
18-5152-020	room 223	north wall	FLSH	09/05/18 7:20
18-5152-021	ez h2o	by rm 212	FDRW	09/05/18 7:22
18-5152-022	ez h2o	by rm 212	FLSH	09/05/18 7:23
18-5152-023	2nd fl hall	by rm 204	FDRW	09/05/18 7:24
18-5152-024	2ndfl hall	by rm 204	FLSH	09/05/18 7:25



Case Narrative

KOMENSKY ELEMENTARY SCHOOL

Lab File ID: **18-5152**

Project ID: **Komensky Elementary School**

Date Received: **September 05, 2018**


All quality control criteria, as outlined in the methods, have been met except as noted below or on the following analytical report.

Sample Batch Comments:

Sample acceptance criteria were met.

The following is a definition of flags that may be used in this report:

Flag	Description	Flag	Description
A	Method holding time is 15 minutes from collection. Lab analysis was performed as soon as possible.		
B	Analyte was found in the method blank.	L	LCS recovery outside control limits.
<	Analyte not detected at or above the reporting limit.	M	MS recovery outside control limits; LCS acceptable.
C	Sample received in an improper container for this test.	P	Chemical preservation pH adjusted in lab.
D	Surrogates diluted out; recovery not available.	Q	Result was determined by a GC/MS database search.
E	Estimated result; concentration exceeds calibration range.	S	Analysis was subcontracted to another laboratory.
G	Surrogate recovery outside control limits.	T	Result is less than three times the MDL value.
H	Analysis or extraction holding time exceeded.	W	Reporting limit elevated due to sample matrix.
J	Estimated result; concentration is less than routine RL but greater than MDL.	N	Analyte is not part of our NELAC accreditation or accreditation may not be available for this parameter.
RL	Routine Reporting Limit (Lowest amount that can be detected when routine weights/volumes are used without dilution.)	ND	Analyte was not detected using a library search routine; No calibration standard was analyzed.



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Analytical Report

Client: KOMENSKY ELEMENTARY SCHOOL
Project ID: Komensky Elementary School

Date Received: 09/05/18
Date Reported: 09/07/18

Lab No:	Sample ID:	Analyte	Result	R.L.	Units	Flags
Total Metals		Method: 200.8R5.4	Preparation Method DW			
18-5152-001	room 108		Date Collected: 09/05/18	Time Collected: 6:57		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-002	room 108		Date Collected: 09/05/18	Time Collected: 6:58		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-003	1st fl hall		Date Collected: 09/05/18	Time Collected: 6:59		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-004	1st fl hall		Date Collected: 09/05/18	Time Collected: 7:00		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-005	room 111		Date Collected: 09/05/18	Time Collected: 7:02		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-006	room 111		Date Collected: 09/05/18	Time Collected: 7:03		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-007	gym		Date Collected: 09/05/18	Time Collected: 7:04		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-008	gym		Date Collected: 09/05/18	Time Collected: 7:05		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-009	1st fl hall		Date Collected: 09/05/18	Time Collected: 7:05		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-010	1st fl hall		Date Collected: 09/05/18	Time Collected: 7:06		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292


1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Analytical Report

Client: KOMENSKY ELEMENTARY SCHOOL
Project ID: Komensky Elementary School

Date Received: 09/05/18
Date Reported: 09/07/18

Lab No:	Sample ID:	Analyte	Result	R.L.	Units	Flags
18-5152-011	room 125		Date Collected: 09/05/18	Time Collected: 7:08		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-012	room 125		Date Collected: 09/05/18	Time Collected: 7:10		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-013	room 129		Date Collected: 09/05/18	Time Collected: 7:12		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-014	room 129		Date Collected: 09/05/18	Time Collected: 7:13		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-015	1st fl hall		Date Collected: 09/05/18	Time Collected: 7:15		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-016	1st fl hall		Date Collected: 09/05/18	Time Collected: 7:16		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-017	2nd fl east hall		Date Collected: 09/05/18	Time Collected: 7:17		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-018	2nd fl east hall		Date Collected: 09/05/18	Time Collected: 7:18		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-019	room 223		Date Collected: 09/05/18	Time Collected: 7:19		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-020	room 223		Date Collected: 09/05/18	Time Collected: 7:20		
Analysis Date:	09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	



**First
Environmental
Laboratories, Inc.**

IL ELAP / NELAC Accreditation # 100292

1600 Shore Road • Naperville, Illinois 60563 • Phone (630) 778-1200 • Fax (630) 778-1233

Analytical Report

Client: KOMENSKY ELEMENTARY SCHOOL
Project ID: Komensky Elementary School

Date Received: 09/05/18
Date Reported: 09/07/18

Lab No:	Sample ID:	Analyte	Result	R.L.	Units	Flags
18-5152-021	ez h2o		Date Collected: 09/05/18	Time Collected: 7:22		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-022	ez h2o		Date Collected: 09/05/18	Time Collected: 7:23		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-023	2nd fl hall		Date Collected: 09/05/18	Time Collected: 7:24		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	
18-5152-024	2ndfl hall		Date Collected: 09/05/18	Time Collected: 7:25		
	Analysis Date: 09/06/18			Preparation Date: 09/06/18		
		Lead	<2.00	2.00	ug/L	



Chain of Custody Record for Lead Analysis School/Location Information Header

Complete the header information on this worksheet for each school building or separate ISBE ID. Replicate this sheet if necessary for additional buildings or ISBE ID numbers. Enter individual sample information on the worksheet labeled "Page 2".

Please complete all of the fields below that have been shaded in yellow. Complete the lilac shaded cells if the data report should go to someone other than the school contact.

School/Facility Information	
School/District Name:	Komensky Elementary School
Address:	2515 Cuyler Ave.
City/State/Zip:	Berwyn Il 60402
School Contact:	George Lambesis
School Contact Phone:	(708) 303-4809
School Contact email:	glambesis@bsd100.org
ISBE ID:	06-016-1000-02
Building ID:	0001
Building Description:	Elementary School

Client/Report Information	
If these samples were collected by an outside consultant for the school, please complete the following fields:	
Report to (Company Name):	South Berwyn School District 100
Report to (Name):	George Lambesis
Report to (e-mail):	glambesis@bsd100.org
Report to (phone):	(708) 303-4809

Sampling Information	
Sampled by:	Alex Legare
Sampler Initials:	AL
Date Building Last Used:	9/4/18
Time Building Last Used:	10:30 PM

Sample details are provided on the following sheets.

Comments: _____

Relinquished By:

[Signature]

Date/Time:

9/5/18 1105

Received By:

[Signature]

Date/Time:

9/5/18 1105

Date Collected	Time Collected	Bottle No.	Field Sample ID	Sample Location Description	Fixture Type	Sample Type	Sample Volume	Analysis	Lab Sample ID
9/5/2018	6:57	1	room 108	west wall	fountain	first draw	250 ml	Lead 200.8	18-JTSB-001
9/5/2018	6:58	2	room 108	west wall	fountain	flush	250 ml	Lead 200.8	002
9/5/2018	6:59	3	1st fl hall	by 2n door	fountain	first draw	250 ml	Lead 200.8	003
9/5/2018	7:00	4	1st fl hall	by 2n door	fountain	flush	250 ml	Lead 200.8	004
9/5/2018	7:02	5	room 111	south wall	fountain	first draw	250 ml	Lead 200.8	005
9/5/2018	7:03	6	room 111	south wall	fountain	flush	250 ml	Lead 200.8	006
9/5/2018	7:04	7	gym	north wall	fountain	first draw	250 ml	Lead 200.8	007
9/5/2018	7:05	8	gym	north wall	fountain	flush	250 ml	Lead 200.8	008
9/5/2018	7:05	9	1st fl hall	by 5n door	fountain	first draw	250 ml	Lead 200.8	009
9/5/2018	7:06	10	1st fl hall	by 5n door	fountain	flush	250 ml	Lead 200.8	010
9/5/2018	7:08	11	room 125	south wall	fountain	first draw	250 ml	Lead 200.8	011
9/5/2018	7:10	12	room 125	south wall	fountain	flush	250 ml	Lead 200.8	012
9/5/2018	7:12	13	room 129	north wall	fountain	first draw	250 ml	Lead 200.8	013
9/5/2018	7:13	14	room 129	north wall	fountain	flush	250 ml	Lead 200.8	014
9/5/2018	7:15	15	1st fl hall	by rm 137	fountain	first draw	250 ml	Lead 200.8	015
9/5/2018	7:16	16	1st fl hall	by rm 137	fountain	flush	250 ml	Lead 200.8	016
9/5/2018	7:17	17	2nd fl east hall	by rm 235	fountain	first draw	250 ml	Lead 200.8	017
9/5/2018	7:18	18	2nd fl east hall	by rm 235	fountain	flush	250 ml	Lead 200.8	018
9/5/2018	7:19	19	room 223	north wall	fountain	first draw	250 ml	Lead 200.8	019
9/5/2018	7:20	20	room 223	north wall	fountain	flush	250 ml	Lead 200.8	020
9/5/2018	7:22	21	ez h2o	by rm 212	fountain	first draw	250 ml	Lead 200.8	021
9/5/2018	7:23	22	ez h2o	by rm 212	fountain	flush	250 ml	Lead 200.8	022
9/5/2018	7:24	23	2nd fl hall	by rm 204	fountain	first draw	250 ml	Lead 200.8	023
9/5/2018	7:25	24	2nd fl hall	by rm 204	fountain	flush	250 ml	Lead 200.8	024
		25					250 ml	Lead 200.8	