



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: MAS JH 22

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 10/25/2016 17:31
Reported: 12/30/2016 16:17

Analytical Testing Parameters

Client Sample ID: 31
Lab Sample ID: J6K0429-01
Sample Type: Grab
Collection Date: 10/25/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0013, 0.015, 0.001, mg/L, 12/20/16 0910, 12/23/16 2020

Analytical Testing Parameters

Client Sample ID: 43
Lab Sample ID: J6K0429-02
Sample Type: Grab
Collection Date: 10/25/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.013, 0.015, 0.001, mg/L, 12/20/16 0910, 12/23/16 2025

Analytical Testing Parameters

Client Sample ID: 38
Lab Sample ID: J6K0429-03
Sample Type: Grab
Collection Date: 10/25/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.011, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2027



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 33
Lab Sample ID: J6K0429-04
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:15

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0055, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2029

Analytical Testing Parameters

Client Sample ID: 54
Lab Sample ID: J6K0429-05
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.018, 0.015, 0.001, mg/L, G, 12/20/16 0934, 12/23/16 2030

Analytical Testing Parameters

Client Sample ID: 51
Lab Sample ID: J6K0429-06
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0019, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2032



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 39
Lab Sample ID: J6K0429-07
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0074, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2038

Analytical Testing Parameters

Client Sample ID: 53
Lab Sample ID: J6K0429-08
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.014, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2040

Analytical Testing Parameters

Client Sample ID: 60
Lab Sample ID: J6K0429-09
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2041



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 36
Lab Sample ID: J6K0429-10
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.017, 0.015, 0.001, mg/L, G, 12/20/16 0934, 12/23/16 2043

Analytical Testing Parameters

Client Sample ID: 29
Lab Sample ID: J6K0429-11
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.011, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2045

Analytical Testing Parameters

Client Sample ID: 37
Lab Sample ID: J6K0429-12
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0051, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2049



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 28
Lab Sample ID: J6K0429-13
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.011, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2050

Analytical Testing Parameters

Client Sample ID: 26
Lab Sample ID: J6K0429-14
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0052, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2052

Analytical Testing Parameters

Client Sample ID: 35
Lab Sample ID: J6K0429-15
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.012, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2054



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 23
Lab Sample ID: J6K0429-16
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0074, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2059

Analytical Testing Parameters

Client Sample ID: 34
Lab Sample ID: J6K0429-17
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:15

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0086, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2101

Analytical Testing Parameters

Client Sample ID: 61
Lab Sample ID: J6K0429-18
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0012, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2103



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 48
Lab Sample ID: J6K0429-19
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0027, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2105

Analytical Testing Parameters

Client Sample ID: 49
Lab Sample ID: J6K0429-20
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0035, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2107

Analytical Testing Parameters

Client Sample ID: 46
Lab Sample ID: J6K0429-21
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0049, 0.015, 0.001, mg/L, 12/20/16 0934, 12/23/16 2116



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 52
Lab Sample ID: J6K0429-22
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.024, 0.015, 0.001, mg/L, G, 12/20/16 0934, 12/23/16 2121

Analytical Testing Parameters

Client Sample ID: 50
Lab Sample ID: J6K0429-23
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0067, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2123

Analytical Testing Parameters

Client Sample ID: 32
Lab Sample ID: J6K0429-24
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0012, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2125



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 42
Lab Sample ID: J6K0429-25
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0032, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2126

Analytical Testing Parameters

Client Sample ID: 21
Lab Sample ID: J6K0429-26
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0068, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2128

Analytical Testing Parameters

Client Sample ID: 22
Lab Sample ID: J6K0429-27
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0016, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2134



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 27
Lab Sample ID: J6K0429-28
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0044, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2135

Analytical Testing Parameters

Client Sample ID: 47
Lab Sample ID: J6K0429-29
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0051, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2137

Analytical Testing Parameters

Client Sample ID: 30
Lab Sample ID: J6K0429-30
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0015, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2139



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 25
Lab Sample ID: J6K0429-31
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0068, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2141

Analytical Testing Parameters

Client Sample ID: 45
Lab Sample ID: J6K0429-32
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.045, 0.015, 0.001, mg/L, G, 12/20/16 0956, 12/23/16 2144

Analytical Testing Parameters

Client Sample ID: 24
Lab Sample ID: J6K0429-33
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0058, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2146



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Analytical Testing Parameters

Client Sample ID: 41
Lab Sample ID: J6K0429-34
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0034, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2148

Analytical Testing Parameters

Client Sample ID: 40
Lab Sample ID: J6K0429-35
Sample Type: Grab

Collection Date: 10/25/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0033, 0.015, 0.001, mg/L, 12/20/16 0956, 12/23/16 2150

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
G: Result fails applicable NYS drinking water standards
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, Item, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. Dayville (NY 11549) NY Lab ID No: 11549 New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0429

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield
Division Manager
12/30/2016 16:17

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

MAS JH ZZ
 Billing/Invoiced
 MNY Workorder #

Client Information
 Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES
 Address: 20104 NYS Route 3
 Watertown, NY 13601
 Contact: Ray Filley
 Phone: 315-779-7054
 Project: Lead Testing
 Quote ID: _____
 Rush TAT Bur. Days: 3 2-5 5-7 7-10
 Release to DOH: Yes
 Email Results: Yes
 Fax Results: Yes
 PO#: _____
 Date Req: _____
 Email: rfilley@boces.com
 Fax: ffhack@bocef3.com

Sample Information		Matrix		Signature		Date/Time	
Description/Location	Data	Time	Initial	Type	Signature	Date/Time	Comments
1 31	10/25	714	LS		Linda Shaw	10/31 08:30	
2 43		720			Jessica Howard	10/31 12:00	
3 38		719					
4 33		715					
5 84		725					
6 51		708					
7 39		719					
8 53		725					

Sample Information		Matrix		Signature		Date/Time	
Description/Location	Data	Time	Initial	Type	Signature	Date/Time	Comments
200.8 Lead	P						
250							
HNO3							

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: _____
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W

Accepted: YES NO
 Container Material: _____
 Container Size (in ml): _____
 Preservative: _____
 Comments/Field Data: _____

Number of Containers for Analysis Requested: _____

Print Name and Company: _____
 Signature: _____
 Date/Time: _____

J6K0429

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MAS JH ZZ

MNY Workorder #

Analytix Requested

Client Information		Billing/Invoicing		Analytix Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Heikimer, Osella BOCES Address: 20104 NYS Route 3 Watertown, NY 13601 Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing Quote ID:		PO#: _____ Date Req.: _____ Refuse to DOH: Yes Email Results: Yes Fax Results: Yes		2008 Lead P 250 HNO3		Ice: YES NO Cooler: YES NO Sample Temp: _____ Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted: YES NO Container Material: _____ Container Size (in qt): _____ Preservative: _____	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			Comments/Field Data
1 600	10/25	7:17	LS				
2 360		7:19					
3 29		7:11					
4 37		7:19					
5 28		7:11					
6 26		7:10					
7 35		7:19					
8 23		7:10					
Sampled: LINDA SHAW				Signature		Date/Time	
				LINDA SHAW		10/31/08	
Received:							
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MAS SH ZZ
 Billing/Invoice

MNY Workorder #

Client Information

Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida-ROCHS
 Address: 20104 NYS Route 3
 Watertown, NY 13601
 Contact: Ray Filley
 Phone: 315-779-7054
 Project: Lead Testing
 Quote ID: _____
 Rush TAT Bus. Days: 2-3 5-7 7-10
 Release to DOH: Yes
 Email Results: Yes
 Fax Results: Yes

PO#: _____ Date Req: _____
 Email: rfilley@boces.com / fhawk@boces.com

Sample Information		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Initial	Method Type	Accepted?
34	10/1/25	7:15	LS	250 HNO3	YES NO
61		7:17			YES NO
40		7:25			YES NO
49		7:25			YES NO
46		7:23			C W
52		7:25			YES NO
50		7:25			YES NO
52		7:14			YES NO

Number of Containers for Analysis Requested

Comments/Fluid Data

Signature: LINDA SHAW
 Date/Time: 10/31/2020

Print Name and Company: LINDA SHAW

Received: _____
 Received: _____
 Received: _____
 Received: _____
 Received: _____

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Client Information
 Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES
 Address: 20104 NYS Route 3
 Watertown, NY 13601
 Contact: Ray Filley
 Phone: 315-779-7054
 Project: Lead Testing
 Quote ID:
 Rush TAT Bus. Days: 3 2-5 8-7 7-10
 Release to DOM: Yes
 Email Results: Yes
 Fax Results: Yes
 PO#:
 Date Req:
 Billing/Invoice:
 MMS JH ZZ
 rfilley@boces.com / rfilley@boces.com

Sample Information		Matrix Type		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial	Matrix	Type	Accepted?	Container Material
1 412	10/25	7:17	LS	HNO3		YES	NO
2 21		7:08					
3 22		7:08					
4 27		7:11					
5 47		7:22					
6 30		7:12					
7 25		7:10					
8 45		7:20					

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: YES NO
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted: YES NO
 Container Material:
 Container Size (in MI)
 Preservative
 Comments/Field Data

Signature: Linda Shaw Date/Time: 10/31/03
 Received:
 Received:
 Received:
 Received:
 Received:

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

