

**Summary of LCCA Drinking Water Lead Exceedances at Soule Road. 2/20/2019**

School Name	Location ID	Sample Type	Sample Location Name	Analysis Name	Result	EPA Action Limit	Unit of Measurement	Actions Taken
Soule Road	016P	Primary	Room 18 Faucet	Lead	0.031	0.015	Mg/L	Daily flushing, labeled as hand-washing only
Soule Road	018P	Primary	Room 19 Faucet	Lead	0.14	0.015	Mg/L	Daily flushing, labeled as hand-washing only
Soule Road	020P	Primary	Room 20 Faucet	Lead	0.018	0.015	Mg/L	Daily flushing, labeled as hand-washing only
Soule Road	022P	Primary	Room 15 Faucet	Lead	0.018	0.015	Mg/L	Daily flushing, labeled as hand-washing only
Soule Road	024P	Primary	Room 12 Faucet	Lead	0.016	0.015	Mg/L	Daily flushing, labeled as hand-washing only
Soule Road	026P	Primary	Room 14 Faucet	Lead	0.2	0.015	Mg/L	Daily flushing, labeled as hand-washing only
Soule Road	030P	Primary	Room 11 Faucet	Lead	0.04	0.015	Mg/L	Daily flushing, labeled as hand-washing only
Soule Road	033P	Primary	Former Staff Lounge	Lead	0.055	0.015	Mg/L	Daily flushing, labeled as hand-washing only
Soule Road	034P	Primary	Room 10 Faucet	Lead	0.023	0.015	Mg/L	Daily flushing, labeled as hand-washing only
Soule Road	036P	Primary	Room 5 Faucet	Lead	0.016	0.015	Mg/L	Daily flushing, labeled as hand-washing only
	sboyd							