

Andrew Johnson Complex

104 Charles Street

Town Administrator Todd Smith

Assessment October 23, 2018



LOCATION SUMMARY

This facility has a gymnasium, employee fitness center with shower facilities, and a stage area. The Andrew Johnson Center is also home to Main Street : Greeneville, Greeneville City Employee's Credit Union, and the Greeneville/Greene County History Museum. The Parks and Recreation Department is responsible for maintenance on all areas of the building.

Responsible for Andrew Johnson ADA Transition Plan Section

Director Butch Patterson – 423-638-3143 / bpatterson@greenevilletn.gov

Office Manager / Program Supervisor Lisa Scott Fisher – 423-638-3143 / lfisher@greenevilletn.gov

Maintenance Supervisor John Darnell – 423-823-0720 / jdarnell@greenevilletn.gov

ADA Checklist for Existing Facilities

Priority 1 – Approach & Entrance

Based on the 2010 ADA Standards for Accessible Design



Project: ADA Assessment Greeneville, TN

Building: Andrew Johnson Complex – third floor Museum

Location: 101 W. McKee Street

Date: Dec 20, 2018

Surveyors

Contact Information

An accessible route from site arrival points and an accessible entrance should be provided for everyone.

Priority 1 – Approach & Entrance

Comments

Possible Solutions

1.1 Is there at least one route from site arrival points (parking, passenger loading zones, public sidewalks and public transportation stops) that does not require the use of stairs? [See 2010 ADA Standards for Accessible Design – 206.2.1]

No

If yes, location of route:




Photo #:

- Add a lift if site constraints prevent other solutions

Entrance

1.37 Is the main entrance accessible?

No



- Redesign to make it accessible


-
-

Photo #:


1.38 If the main entrance is not accessible, is there an alternative accessible entrance?

No

NA



Can the alternative accessible entrance be used independently and during the same hours as the main entrance?



- Designate an entrance and make it accessible

Photo #:

Interior Accessible Route – Third floor is used as storage

2.2 Are all public spaces on at least one accessible route?
[206.2.4]

No




Photo #:

- Create accessible route
-
-